NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report REC WATEFVELL REPORT

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

MAY 8 19 Please type or print) WATER RESOURCESVEDEPTE that line)

State Well No. 155/13E -23

State Permit No. ..

SALEM. OREGON				
(1) OWNER:	(10) LOCATION OF WELL:			
Name Military Dept., State of Oregon	County Deschutes Driller's well number			
Address 2150 Fairgrounds Rd., N.E.	14 N Section 23 T. 158	R.	13E.	W.M.
Salem, Oregon 97303	Bearing and distance from section or subdivi	sion corne	er	-
(2) TYPE OF WORK (check):			, ,,,,	
New Well Deepening Reconditioning Abandon				
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed	well		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	W CIA.	390	24
Rotary Driven Domestic Industrial Municipal	0.7.5			ft.
Caple	Static level 3/5 ft. below land Artesian pressure lbs. per square			<u>-20-19</u>
CASING INSTALLED: Threaded □ Welded WE	(12) WEIT LOC.			8"
6 "Diam. from +2 ft. to 362 ft. Gage 250	Diameter of well		•	
"Diam. fromft. Gage				20 ft.
" Diam, from ft. to ft. Gage	Formation: Describe color, texture, grain size and show thickness and nature of each strat	um and a	lauifer pe	netrated.
PERFORATIONS: Perforated? Yes No.	with at least one entry for each change of form position of Static Water Level and indicate pr	ation, Rep	ort each	change in
Type of perforator used	MATERIAL	From	То	swL
Size of perforations in. by in.	Tep-Soil	0	4	
perforations fromft. toft.	Lava	4	107	
perforations from ft. to ft.	Brewn Conglom.	107	113	
perforations from ft. to ft.	Lava	113	143	
(7) SCREENS: Well screen installed? X Yes No	Brown Sandstone Conglom.	143	154	
Manufacturer's Name Jehnson	Lava	154	200	
Type Telescepic Model No. 10 slot	Broken Lava & Crevices	200	210	
Diam. 6" Slot size 10 Set from 378 ft. to 420 ft.	Brown Conslor	210	21.5	
Diam. Slot size Set from ft. to ft.	Brown Conglom. Lava	215 224	224	
(0) XXXXX X MXXCDC	Brown Sandstone	283	283 320	`
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Black Sand	320	350	··
s a pump test made? 🗷 Yes 🗌 No If yes, by whom? Contractor	Brown Sandstone Conglom.	350	390	
feld: 30 gal./min. with 0 ft. drawdown after 1 hrs.	Black Sand, Water-Bearing	390	425	
" " "				
H	* ***			
Poilor test				
gai./min. with ft. drawdown after hrs. artesian flow g.p.m.	2 No. 10			
nperature of water 53 peth artesian flow encountered	Work started 10-30 19 78 Complete	ted 2-1	6	19 79
(9) CONSTRUCTION:	Date well drilling machine moved off of well	2 -		19 79
Well seal—Material used Cement	Drilling Machine Operator's Certification			
Well sealed from land surface to 25 ft.	This well was constructed under my	direct	superv	vision.
Diameter of well bore to bottom of seal10in.	Materials used and information reported best knowledge and belief.	above a	are true	to my
Diameter of well bore below seal		D-4 E	5-3	79
Number of sacks of cement used in well sealsacks	[Signed] Null Machine Operator) Date 5-3, 1979			
How was cement grout placed? Pressure grout	Drilling Machine Operator's License No.	<u> </u>	2	
	Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is			
Was a drive shoe used? Yes Ano Plugs Size: location ft.	true to the best of my knowledge and belief.			
Did any strata contain unusable water? Yes No	Name Orvail Buckner Well Drilling, Inc. (Person, firm or corporation) (Type or print)			
Type of water? depth of strata	Address 1686 N.E. Negus Hay, Reg			
Method of sealing strata off	() 10 18	::::::::::::::::::::::::::::::::::::::	.xaxay	
Was well gravel packed? Tyes K No Size of gravel:	[Signed]	~	***********	***************************************
·	(Water Well Control	actor)	70	
Gravel placed from ft. to ft.	Contractor's License No. 608 Date	J-5-/	79	, 19