NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
APR 20 1979
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 16S/11E-19
State Permit No. DESC-4053

(1) OWNER:
Name Frank Cibelli
Address 62575 Dixon Loop Bend, Ore 97701

(2) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [X] Driven []
Cable [] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):
Domestic [] Industrial [X] Municipal []
Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:
Threaded [] Welded [X]
8" Diam. from +1 ft. to 100 ft. Gage .250
6" Diam. from +1 ft. to 226 ft. Gage .188
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
air lifting 30 GPM with 8" DD "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 24 ft.
Diameter of well bore to bottom of seal 12 in. 6" 326-338
Diameter of well bore below seal 8" from 24 to 326
Number of sacks of cement used in well seal 21 sacks
How was cement grout placed? pumped from 24 to 0
Was a drive shoe used? [] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Deschutes Driller's well number
NE ¼ NW ¼ Section 19 T. 16S R. 11E W.M.
Bearing and distance from section or subdivision corner
450' S & 200' W of N ¼ corner Sec 19

(11) WATER LEVEL: Completed well.
Depth at which water was first found 281 ft.
Static level 281 ft. below land surface. Date 3/21/79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 338 ft. Depth of completed well 338 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
hvy brn soil & bldrs	0	5	
tan clay congl crs	5	24	
white pumice	24	99	
brn metamorphic rock	99	173	
redish brn metamorphic rock	173	186	
brn ss congl fine	186	198	
med gravel w/brn pumice	198	207	
yellow clay med gravel	207	218	
fine to med gravel w/brn sand (caving-2yds concrete200-281)	218	281	281
crs gravel & blk ss layers (WB)	281	300	
blk fine sand(caving (WB)	300	326	
blk basalt w/ seams (WB)	326	338	

Work started 3/8 19 79 Completed 3/21 1979
Date well drilling machine moved off of well 3/21 19 79

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] John V. Johnson Date 3/27, 19 79
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1039

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Johnson Well Drilling
(Person, firm or corporation) (Type or print)
Address 3626 NW Coyner Redmond, Ore
[Signed] John V. Johnson
(Water Well Contractor)
Contractor's License No. 595 Date 3/27, 19 79

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119