The original and first copy of this report are to be filed with the CE CE V WATER WELL REPORT WATER RESOURCES DEPARTMENT, State Well No. 163/115-2591 SALEM, OREGON 97310
within 30 days from the date APR 5 1979
(Do not write above this like) of well completion.
WATER RESOURCES DEPT, State Permit No. ..... SALEM. OREGON (10) LOCATION OF WELL: (1) OWNER: Name R.J. Anliker Driller's well number 28 County Deschutes Address 65175 Gerking Mkt Rd. Bend. Or 97701 14 NE 14 Section 25 T. 16S R. 11E W.M. Bearing and distance from section or subdivision corner 20 feet (2) TYPE OF WORK (check): from the West and 20 feet from the South Subdivision line New WellXX Deepening [ Reconditioning [ Abandon [7] If abandonment, describe material and procedure in Item 12. (11) WATER LEVEL: Completed well. (3) TYPE OF WELL: (4) PROPOSED USE (check): Depth at which water was first found Rotary XXX Driven □ Domestic Y Industrial | Municipal | ft. below land surface. Date 3\_21\_79 Static level 565 Cable Jetted Bored | Irrigation | Test Well | Other Dug Artesian pressure none lbs. per square inch. Date CASING INSTALLED: Threaded | Welded | Welded (12) WELL LOG: Diameter of well below casing ..... 8th "Diam. from +1 ft. to 59 ft. Gage 250 Depth drilled 610 ft. Depth of completed well Formation: Describe color, texture, grain size and structure of materials: and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in PERFORATIONS: position of Static Water Level and indicate principal water-bearing strata. Perforated? | Yes XX No. Machine sawed Type of perforator used MATERIAL From SWT. in. by 3/8 Size of perforations Clay Topsoil 0 468 perforations from 570 ft. to Clay Stone w/ Boulders 33 Gravel 34 43 Tan Sandstone w/ Pumice 44 120 perforations from ft. to Red Rock 121 158 (7) SCREENS: Well screen installed? Yes XXKNo Brown Sandstone Congl 159 270 Manufacturer's Name ..... Basalt w/ crevices 271 363 Brown sandstone congl 364 610 Diam. Slot size ..... Set from ..... ft. to .... ft. Diam. ..... Slot size ...... Set from ..... ft. to ..... ft. (8) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? 

Yes XXNo If yes, by whom? Vield: gal./min. with ft. drawdown after nis doesn't nec'essarily mean that this is all the well will produce, as we can only bail that Bailer test 10 gal./min. with 0 ft. drawdown after 1 fast Artesian flow none g.p.m. perature of water 52 Depth artesian flow encountered ......ft. Work started 3-14-79 Completed 3-29-79 19 Date well drilling machine moved off of well (9) CONSTRUCTION: Portland, Cement # 1 **Drilling Machine Operator's Certification:** -Well seal-Material used ...... This well was constructed under my direct supervision. Well sealed from land surface to \_\_\_\_\_\_\_ 19 ft. Materials used and information reported above are true to my best knowledge and belief Diameter of well bore to bottom of seal .......12........... in. Number of sacks of cement used in well seal \_\_\_\_\_\_ 50\_\_\_\_ sacks Drilling Machine Operator's License No. .. How was cement grout placed? \_\_\_\_Pumped\_\_\_\_ Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name Bill Williams Well Drilling Was a drive shoe used? 🗌 Yes 🗶 No Plugs ...... Size: location .......... Did any strata contain unusable water? ☐ YesXXXNo P.O. Box 334, Redmond, Or 97756 Type of water? depth of strata Method of sealing strata off Was well gravel packed? ☐ Yes XX No Size of gravel: Contractor's License No. 713 Date 3-29-79 Gravel placed from ...... ft. to ..... ft.

NOTICE TO WATER WELL CONTRACTOR