NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.
(Keith)

DESC 483

RECEIVED
APR 3 1974
STATE ENGINEER
SALEM, OREGON

ba

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 17S/12E-8
State Permit No. Deschutes 440710 (21190201)

(1) OWNER:
Name Kieth Ramsey Sr.
Address 1609 Ramsey Rd. Bend, Oreg. 97701

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
8" Diam. from +2 ft. to 30 ft. Gage .250
6" Diam. from +5 ft. to 200 ft. Gage .188
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
~~Bailer test~~ Air Test 15 gal./min. with 50 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 51 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 10 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Driller's well number
NE ¼ NW ¼ Section 8 T.17S R. 12 E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 185 ft.
Static level 168 ft. below land surface. Date 3-28-74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 216 ft. Depth of completed well 215 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Sand, pumice	0	3	
Boulders	3	11	
Lava, frac.	11	14	
Lava, grey	14	38	
Lava, frac.	38	40	
Lava, grey	40	72	
Sediments, clay	72	75	
Gravel	75	115	
Pumice, brown	115	125	
Pumice, brn, gravel	125	195	168
Pumice, white	195	215	

Work started MARCH 11 1974 Completed Mar 28 1974
Date well drilling machine moved off of well Mrr. 28 1974

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Lloyd Reid Date April 1 1974
(Drilling Machine Operator)
Drilling Machine Operator's License No. 130

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Reed's Well Drilling
(Person, firm or corporation) (Type or print)
Address Rt. 2 Box 1573-A Bend, Ore.
[Signed] Lloyd Reid
(Water Well Contractor)
Contractor's License No. 443 Date April 1, 1974

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119