NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED APR 11 1969 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

DESC 5263

State Well No. 18/12-18dd

State Permit No.

(1) OWNER:
Name Paul Ramsay
Address Bend Ore

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☑ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
8" Diam. from 0 ft. to 345 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used Torch Cut
Size of perforations 1/8 in. by 6 in.
140 perforations from 345 ft. to 365 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 354 ft. below land surface Date 3-25-9
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 15 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 54 Was a chemical analysis made? ☐ Yes ☑ No

(10) CONSTRUCTION:
Well seal—Material used Cement
Depth of seal 20 ft. ft.
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☐ Yes ☑ No
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County Deschutes Driller's well number
S.E. ¼ S.E. ¼ Section 18 T. 18S R. 12E W.M.
Bearing and distance from section or subdivision corner
Way West. Properties

(12) WELL LOG: Diameter of well below casing 8
Depth drilled 348 ft. Depth of completed well 345 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	4	
Lava Boulders	4	32	
Pinhole Lava (Crevices)	32	54	
Red Cinders	54	56	
Broken Lava (Crevices)	56	174	
Brown Conglomerate	174	193	
Black Pumice	193	239	
Red Cinders	239	256	
Lava shale	256	289	
Brown Conglomerate	289	326	
Red Lava	326	348	
Red Cinders	348	365	354

Work started 2-1 1969 Completed 3-25 1969
Date well drilling machine moved off of well 3-25 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Arthur R. Schultz (Drilling Machine Operator) Date 3-29, 1969
Drilling Machine Operator's License No. 357

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Cent. Geo Well Drilling Co. (Person, firm or corporation) (Type or print)
Address Rt #1 Bx. 142 Redmond
[Signed] Arthur R. Schultz (Water Well Contractor)
Contractor's License No. 464 Date 3-29, 1969

(USE ADDITIONAL SHEETS IF NECESSARY)