

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

DESC 5491

WATER WELL REPORT

STATE OF OREGON (Please type or print)

RECEIVED

State Well No. 18/12-30

State Permit No.

(1) OWNER:

Name Arthur G Keast Address 1444 North Dr. San Jose, Calif.

(2) LOCATION OF WELL:

County Deschutes Driller's well number 1/4 NW 1/4 Section 30 T. 18S R. 12E W.M. Bearing and distance from section or subdivision corner Plot 92, Block S Deschutes River woods Bend,

(3) TYPE OF WORK (check):

Well [ ] Deepening [x] Reconditioning [ ] Abandonment [ ]

(4) PROPOSED USE (check):

Domestic [x] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

Threaded [ ] Welded [ ] Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [ ] Yes [ ] No Type of perforator used Size of perforations in. by in.

(8) SCREENS:

Well screen installed? [ ] Yes [ ] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Depth of seal ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? [ ] Yes [ ] No Depth Was a drive shoe used? [ ] Yes [ ] No Was well gravel packed? [ ] Yes [ ] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [ ] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 409 ft. below land surface Date 2/23/67 Artesian pressure lbs. per square inch Date 2/23/67

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [ ] No If yes, by whom? Eng'l's Yield: 20 gal./min. with 1 ft. drawdown after 4 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 53 Was a chemical analysis made? [ ] Yes [x] No

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 434 ft. Depth of completed well 434 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries: Grey Basalt (424-432), Red clinders (432-434)

Work started 3/16/67 Completed 3/21/67 Date well drilling machine moved off of well 3/22/67

(13) PUMP:

Manufacturer's Name Burbly Type: sub H.P. 3

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Reeds Drilling (Person, firm or corporation) Address 1142 Galveston Ave Drilling Machine Operator's License No. 400 [Signed] Sleep Reel (Water Well Contractor) Contractor's License No. 443 Date 4/11/67, 19