WATER WELL/REPORT STATE OF OREGON DESC

RECEIVED

MAR 1 1 1985

State Well No.	20\$10E-251
State Permit No	Ohen

WATER RESOURCES DEPT SALEN, OREGON

1) OWNER:	(10) LOCATION OF WELL: See $\#$	354-84-4	
Name Oregon Water Wonderland Imp. Dist.		number 366-85-3	
Address 55579 S. Century Drive	NW 4 NW 4 Section 25 T. 20S		
City Bend State Oregon	Tax Lot # Lot 27 Blk 3		
2) TYPE OF WORK (check):	Address at well location: Oregon Water	Wonderland	
New Well □ Deepening M Reconditioning □ * Abandon □			
f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 14	<u>ft.</u>	
· · · · · · · · · · · · · · · · · · ·	-	and surface. Date $2-18-8$	
Rotary Air Driven Domestic Industrial Municipal Colory Mud Dug Irrigation Test Well Other I	Artesian pressure lbs. pe	r square inch. Date	
Bored □ Thermal: Withdrawal □ Reinjection □	(12) WELL LOG: Diameter of well below casing		
(5) CASING INSTALLED: Steel X Plastic	Depth drilled 390 ft. Depth of completed well 385 ft.		
5) CASING INSTALLED: Steel See Plastic Threaded Welded Description	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level		
8" Diam. from +15 ft. to-3835t. Gauge 250			
	and indicate principal water-bearing strata.		
LINER INSTALLED:	MATERIAL	From To SWL	
	Gray Clay	126 160	
		160 175	
(6) PERFORATIONS: Perforated? □ Yes ♣No Type of perforator used	Gray Clay	175 210	
Size of perforations in. by in.	Black Silt	210 225	
	Green Clay & Silt	225 240	
perforations from	-	240 337	
perforations from	Tan Pumice/Ash/Cinder	337 341	
perforations fromft. toft.	Thin layer Clay/Pumice	341 370	
(7) SCREENS: Well screen installed? Yes No	& Silt		
Manufacturer's Name	Fine Black Sand	370 375	
Type Model No	Coarse Pumice	375 380	
Diam. Slot Size Set from ft. to ft.	Black Sand	380 390 3	
Diam. Slot Size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
wes a pump test made? X Yes □ No If yes, by whom Big 3 Drill.			
.70			
3:19 gal./min. with 335 ft. drawdown after 24 hrs.			
Air test gal/min. with drill stem at ft. hrs.			
Bailer test gal./min. with ft. drawdown after hrs.			
Artesian flow g.p.m.	<u> </u>		
operature of water 4.70 Depth artesian flow encountered ft.		10.00	
(A) CONCERNICATION	Work started 2-11 19 85 Complete Date well drilling machine moved off of well 2-		
(9) CONSTRUCTION: Special standards: Yes □ No 2 Well seal—Material used Undistrubed		22 19 85	
Well sealed from land surface toft.	Drilling Machine Operator's Certification:	* * 36 . * 3 . 3	
Diameter of well bore to bottom of sealin.	This well was constructed under my direct s and information reported those and true to my b	upervision. Materials used est knowledge and belief	
Diameter of well bore below sealin.	Isimodi A Partie	Date	
Number of sacks of cement used in well seal sacks	Orilling Machine Operator)	•	
How was cement grout placed?	Drilling Machine Operator's License No759.	************************	
	Water Well Contractor's Certification:		
**************************************	This well was drilled under my jurisdiction and this report is true to		
Was pump installed? Type HP Depth ft.	the best of my knowledge and belief.		
Was a drive shoe used? ☐ Yes 🍇 No Plugs Size: location ft.	Name BigThreeDrilling&	PumpService	
Did any strata contain unusable water? X Yes No	Address 1990, NW 35th Redmon		
Type of Water Silt depth of strata 126-370	reimal DV-Xtel		
Method of sealing strata offCased Off	(Water Well Contract		
Was well gravel packed? ☐ Yes ⊠ No Size of gravel:	Contractor's License No. 685 Date 2-2	2, 19. 8.5	
Gravel placed from ft. to ft.	-		