

RECEIVED

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.799) WATER RESOURCES DEPT

JUL 18 1986

DESC 6092

20s/10E-2566 Deep.

(1) OWNER: SALEM, OREGON 97308-86-10 Name Ore. Water Wonderland Water Imp. Dist. Address 55579 S. Century Drive City Bend State Oregon Zip 97707

(9) LOCATION OF WELL by legal description: County Deschutes Township 20S Range 10E Section 25 NW NW Tax Lot Street Address of Well (or nearest address) Oregon Water Wonderland

(2) TYPE OF WORK: [X] Deepen [] Recondition [] Abandon [] New Well [] Rotary Air [] Rotary Mud [X] Cable [] Other

(3) DRILL METHOD: [] Rotary Air [] Rotary Mud [X] Cable [] Other

(10) STATIC WATER LEVEL: 5.5 ft. below land surface. Date 6-20-86 Artesian pressure lb. per square inch. Date

(4) PROPOSED USE: [X] Community [] Industrial [] Irrigation [] Domestic [] Thermal [] Injection [] Other

(11) WELL LOG: Ground elevation

(5) BORE HOLE CONSTRUCTION: Depth of Completed Well 642 ft. Special Standards date of approval --

Table with columns: HOLE Diameter, SEAL Material, Amount sacks or pounds. Row 1: 8, 385-647, UNDISTURBED

Table with columns: Material, From, To, WB?, SWL. Rows include: Fine Blk Sand/Pumice, Greenish Gray clay/sand, Heaving blk sand, Hard pink/gray clay, Hard Gray clay, Gray clay/pumice, Gray Lava, Pumice/broken rock, Broken gray Lava, Coarse blk sand/Sgray, Brkn blk rock/tan clay

How was seal placed? Method [] A [] B [] C [] D [] E [] Other Backfill placed from NO ft. to ft. Material Gravel placed from NO ft. to ft. Size of gravel

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Casing: 8", 385-575, .250, [X] Steel, [] Plastic, [X] Welded, [] Threaded

Final location of shoe(s)

(7) PERFORATIONS/SCREENS: NONE [] Perforations Method [] Screens Type Material

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner

(8) WELL TESTS: Minimum testing time is 1 hour [X] Pump [] Bailer [] Air [] Flowing Artesian Yield gal/min 160 Pumping level 148 Drill stem at Time 1/4 hr 24hrs 1 hr

Date started 5-27-86n Completed 7-10-86

Temperature of water 56° Depth Artesian Flow Found Was a water analysis done? [X] Yes By whom Sun Country Eng. Did any strata contain water not suitable for intended use? [] Too little [] Salty [] Muddy [] Odor [] Colored [] Other Depth of strata:

(unbonded) Water Well Constructor Certification: I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed Date

(bonded) Water Well Constructor Certification: I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Date 7/13/86

Company Big Three Drilling Co. Job No. 398-86-10