

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

DESC  
6201

WATER WELL REPORT

RECEIVED  
JUN 13 1973

20S/11E-5<sup>bb</sup>

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE OF OREGON

(Please type or print)

STATE ENGINEER  
SALEM, OREGON

State Well No.

Permit No.

(Do not write above this line)

(1) OWNER:

Name SunRiver Properties Inc.  
Address SunRiver, Oregon

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded   
12" Diam. from 0 ft. to 58 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " " "  
" " " " " "  
Bailer test 90 gal./min. with 0 ft. drawdown after 3 hrs.  
Artesian flow g.p.m.

(9) CONSTRUCTION:

Well seal—Material used Cement Slurry  
Well sealed from land surface to 58 ft.  
Diameter of well bore to bottom of seal 16 in.  
Diameter of well bore below seal 12 in.  
Number of sacks of cement used in well seal 31 sacks  
Number of sacks of bentonite used in well seal sacks  
Brand name of bentonite  
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off.  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Deschutes Driller's well number  
NW ¼ NW ¼ Section 5 T. 20S R. 11E W.M.  
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 6 to 10 ft. ft.  
Static level 2 ft. below land surface. Date 5/10/73  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12  
Depth drilled 163 ft. Depth of completed well 161 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Dirt and gravel	0	3	
Clay	3	6	
Fine sand & water	6	10	5
Brown Clay	10	21	
Gravel Water	21	30	
Grey clay	30	38	
Gravel	38	40	
Brown clay	40	48	
Coarse sand, gravel	48	58	
Grey lava	58	70	
Grey lava	70	76	
Gravel	76	80	
Grey clay	80	85	
Grey lava, broken	85	135	
Sediments	135	160	
Lava, grey, brown, broken	160	163	

Work started 4/10 1973 Completed 5/10 1973  
Date well drilling machine moved off of well 5/12 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] William D. Dore Date 6/10/1973  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 400

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Reed's Well Drilling  
(Person, firm or corporation) (Type or print)

Address Rt. 2 Box 1573-A Bend, Oreg.

[Signed] Ray Reed  
(Water Well Contractor)

Contractor's License No. 443 Date 6/10/73, 19