

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED
JUL 28 1976
WATER RESOURCES DEPT.
SALEM, OREGON
DESC
7-4-75

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. _____
State Permit No. 215/10E-35

(1) OWNER:
Name Allen Trailer Ct.
Address Rt 2 Box 39
La Pine Or. 97739

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Cable Dug
Driven Jetted Bored
(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED: Threaded Welded
6" Diam. from 0 ft. to 22 1/2 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS: Perforated? Yes No.
Type of perforator used Saw
Size of perforations .025 in. by 2 1/2 in.
1200 perforations from 22 1/2 ft. to 38 1/2 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____
Type Simpson Plastic Model No. I60 Glass
Diam. 6 Slot size .025 Set from 22 1/2 ft. to 38 1/2 ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 12 gal./min. with 6 ft. drawdown after 48 hrs.
" " " " " "
" " " " " "
Baller test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water 46. Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 11 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 1/2 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons
of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:
County Deschutes Driller's well number _____
N.E. 1/4 N.E. 1/4 Section 35 T21 S R. 10 E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.
Depth at which water was first found 24 ft.
Static level 22 ft. below land surface. Date 7/8/76
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 38 1/2 ft. Depth of completed well 38 1/2 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of *Static Water Level* and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	3	
Plumice	3	5	
Clay	5	8	
Clay and Gravel	8	10	
Gravel (fine)	10	15	
Clay and Gravel	15	24	22
Sand Brown (water)	24	36	
Sand and Gravel (fine)	36	38 1/2	

Work started 7/8 1976 Completed 7/9 1976
Date well drilling machine moved off of well 7/9 1976

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Mike Pruden Date 7/17, 1976
(Drilling Machine Operator)
Drilling Machine Operator's License No. 917

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Mike's Well Drilling (Type or print)
(Person, firm or corporation)
Address P.O. Box 613 Pleasant Hill, Or.
[Signed] Mike Pruden (Water Well Contractor)
Contractor's License No. 620 Date 7/17, 1976