WATER WELL REPORT
STATE OF OREGON

DESC 8118

RECEIVED
FEB 15 1985
WATER RESOURCES DEPT.
SALEM, OREGON

PLEASE TYPE OR PRINT IN INK

State Well No. 22S/10E-11dc

State Permit No. .....

(1) OWNER:
Name Mr. G. L. Martin
Address 8404 SE 63rd Ave
City Portland State Ore 97206

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Auger
Rotary Air ☐ Driven ☐
Rotary Mud ☐ Dug ☐
(☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED: Steel ☐ Threaded ☐ Plastic ☐ Welded ☐
5" Diam. from +1 ft. to 35 ft. Gauge Sandwell 125
..." Diam. from ... ft. to ... ft. Gauge ...

LINER INSTALLED:
..." Diam. from ... ft. to ... ft. Gauge ...

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No
Type of perforator used
Size of perforations in. by in.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.

(7) SCREENS: Well screen installed? ☑ Yes ☐ No
Manufacturer's Name Shop made
Type PVC Model No. ...
Diam. 5 Slot Size .020 Set from 25 ft. to 35 ft.
Diam. ... Slot Size ... Set from ... ft. to ... ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? Driller
Yield: 12 gal./min. with 4 ft. drawdown after 4 hrs.
" " " "
Air test gal./min. with drill stem at ft. hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 42 Depth artesian flow encountered ... ft.

(9) CONSTRUCTION: Special standards: Yes ☐ No ☑
Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 8 in.
Diameter of well bore below seal 5 in.
Number of sacks of cement used in well seal 7 sacks
How was cement grout placed? Pressure Grout
Was pump installed? ... Type ... HP ... Depth ... ft.
Was a drive shoe used? ☐ Yes ☑ No Plugs ... Size: location ... ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel: ...
Gravel placed from ... ft. to ... ft.

(10) LOCATION OF WELL:
County Deschutes Driller's well number
SW ¼ SE ¼ Section 11 T. 22 R. 10E W.M.
Tax Lot # Lot Blk Subdivision
Address at well location:

(11) WATER LEVEL: Completed well.
Depth at which water was first found 18 ft.
Static level 16 ft. below land surface. Date 11-20-84
Artesian pressure — lbs. per square inch. Date —

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 35 ft. Depth of completed well 35 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sandy loam	0	3	
Brown Sandy Soil	3	18	
Black Sand	18	35	18

Work started 11-20 1984 Completed 11-20 1984
Date well drilling machine moved off of well 11-20 1984

(unbonded) Water Well Constructor Certification (if applicable):
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] ... Date ..., 19...

Bonded Water Well Constructor Certification:
Bond ... (number) Issued by: ... Surety Company Name
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name ... (Person, firm or corporation) (Type or print)
Address ...
[Signed] John J. Lawson Water Well Constructor
Date ..., 19...

NOTICE TO WATER WELL CONSTRUCTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*45292-690