NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED MAY 25 1964 STATE ENGINEER SALEM, OREGON

DOUG 2600

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 25/7W-32K

State Permit No.

(1) OWNER:
Name DICK ANDERSON
Address UMPQUA OREGON

(2) LOCATION OF WELL:
County DOUGLAS Driller's well number 102
N.W. ¼ S.E ¼ Section 32 T. ~~33~~ 25S R. 7 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 20 ft. Gage ¼
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal PUDDLED CEMENT
Depth of seal 18 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 6 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusuable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 0 ft. below land surface Date 5-8-64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 15 gal./min. with 20 ft. drawdown after 3 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 63 ft. Depth of completed well 63 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
BLACK SOIL	0	3
CLAY STONE SOFT	3	16
CLAYSTONE HARD GREY	16	63

Work started 5-6 1964 Completed 5-8 1964
Date well drilling machine moved off of well 5-8 1964

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME BOEHRS & WALTON
(Person, firm or corporation) (Type or print)
Address BOX 414 OAKLAND ORE
Drilling Machine Operator's License No. 29-30
[Signed] Ed Boehrs
(Water Well Contractor)
Contractor's License No. 267 Date 5-10, 1964

(USE ADDITIONAL SHEETS IF NECESSARY)