NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

DOUG 2797

State Well No. 22S/9W-13

State Permit No.

(1) OWNER:
Name Vincent Stone
Address 7720 SW Greenwood Drive Portland Ore.

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED: Threaded [ ] Welded [X]
6" Diam. from 0 ft. to 55 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? [ ] Yes [X] No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 5 gal./min. with 35 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 49 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Portland Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 4½ sacks
How was cement grout placed? In the annular around the 6" casing
Was a drive shoe used? [ ] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? Good depth of strata 60'
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Douglas Driller's well number
¼ ¼ Section 13 T. 22S R. 9W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 60' ft.
Static level 40' ft. below land surface. Date 2/1/79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 80 ft. Depth of completed well 80 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SOIL	0	4	
yellow clay	4	30	
Blue clay	30	48	
Sand & Fine Gravel	48	50	
Blue sandstone	50	56	
Gray Basalt	56	80	

Work started Jan 29 1979 Completed Feb 1st 1979
Date well drilling machine moved off of well Feb 1st 1979

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Raymond B Beck (Drilling Machine Operator) Date 2/5, 1979
Drilling Machine Operator's License No. 682

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name JOHN T. BECK Sutherlin (Person, firm or corporation) (Type or print) Ore
Address R2 Box 8900
[Signed] John T. Beck (Water Well Contractor)
Contractor's License No. 436 Date 2-4, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119