

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 25 1965 WATER WELL REPORT DOUG 2875 SALEM, OREGON

State Well No. 22/10 W -14 State Permit No.

(1) OWNER:

Name Douglas Co Park Dept
Address Rifle Range Rd. Roseburg Oregon

(2) LOCATION OF WELL:

County Douglas
Bearing and distance from section of subdivision corner 1/4 Section 14 T. 32 S. R. 10 W. W.M.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 31 ft. Gage 350 was

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement
Depth of seal 35 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 30 ft. below land surface Date 6/1/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 35 gal./min. with 2 ft. drawdown after 15 hrs.
Artesian flow g.p.m. Date
Temperature of water 51 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8
Depth drilled 77 ft. Depth of completed well 77 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
sandy dirt	0	4
yellow clay	4	21
blue glauconite	21	63
hard chert	63	77

Work started 5/28/65 Completed 6/1/65 19
Date well drilling machine moved off of well 6/1/65 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Moxwell Drilling (Person, firm or corporation) (Type or print)
Address Rt 2 Box 1169, Roseburg
Drilling Machine Operator's License No 168
[Signed] S. J. Moxwell (Water Well Contractor)
Contractor's License No. 60 Date 6/27/65 19