

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310, within 30 days from the date of well completion.

RECEIVED

OCT 6 1967

WATER WELL REPORT

STATE ENGINEER STATE OF OREGON

SALEM, OREGON (Please type or print) (Do not write above this line)

State Well No. 25/5w-64

State Permit No.

(1) OWNER:

Name M. F. Minick
Address Killgus St. Rt. 15
Oakland

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 21 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations	in. by	in.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level ft. below land surface Date

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

gal./min. with ft. drawdown after hrs.

456 " 180 " 35 "

" than 5" per min "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 56 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal material used cement

Depth of seal 18 ft.

Diameter of well bore to bottom of seal 9 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☒ Yes ☐ No

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Douglas Driller's well number 775
1/4 1/4 Section 5 T.25S R.5W W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
soil. Brown	0	2	
clay yellow	2	10	
claystone blue	2	37	20
water 40.2 P.H.			
claystone blue	37	54	20
water 40.2 P.H.			
sandstone grey	54	56	20
claystone blue	56	76	20
water 40.2 P.H.			
claystone blue	76	98	20
claystone blue	98	200	20
water 40.2 P.H.			
total water 300 P.H.			

Work started 9-17 1967 Completed 9-25 1967

Date well drilling machine moved off of well 9-28 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ralph H. Steiner Date 9-28, 1967
(Drilling Machine Operator)

Drilling Machine Operator's License No. 60

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steiner's well drilling
(Person, firm or corporation) (Type or print)

Address P.O. Box 453 Sutherlin Ore

[Signed] Ralph H. Steiner
(Water Well Contractor)

Contractor's License No. 64 Date 9-28, 1967