

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED
WATER WELL REPORT 24 1967

4955

STATE OF OREGON STATE ENGINEER

(Please type or print)
(Do not write above this line)

State Permit No.

25/6w-23

(1) OWNER:

Name Allen Kuthill
Address Empire Star Route, Box 110
Wahland, Ore

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dig ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 26 ft. Gage 250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 40 ft. below land surface Date 11-19-67

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

1: gal./min. with ft. drawdown after hrs.

" " " "

" 20 " gal per Hour "

Ballor test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 55 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used packed clay

Depth of seal 19 ft.

Diameter of well bore to bottom of seal 9 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☐ Yes ☒ No

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Douglas Driller's well number 776

1/4 1/4 Section 23 T. 25S R. 6W W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 195 ft. Depth of completed well 195 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
soil Brown	0	3	
Clay, yellow	3	15	
Claystone, dark grey	15	45	
Sandstone, grey	45	45 1/2	40
Claystone, dark grey	45 1/2	195	40
20-8 P.H.			

Work started 11-8 1967 Completed 11-19 1967

Date well drilling machine moved off of well 11-20 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ralph H. Steiber Date 11-20, 1967
(Drilling Machine Operator)

Drilling Machine Operator's License No. 60

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steiber's well drilling
(Person, firm or corporation) (Type or print)

Address P.O. Box 1153, Lutherville

[Signed] Ralph H. Steiber
(Water Well Contractor)

Contractor's License No. 64 Date 11-20, 1967