

(Please type or print)

(Do not write above this line)

State Permit No.

97310  
From the date  
completion.

City of Reedsport #2  
P.O. Box 358

TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

TYPE OF WELL:

Driven   
 Jetted   
 Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded

1" Diam. from 0 ft. to 64-4 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated?  Yes  No.

of perforator used

ft perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name Johnson  
PVC Model No.  
4 Slot size 12 Set from 66 ft. to 76 ft.  
Slot size Set from ft. to ft.

WELL TESTS:

Drawdown is amount water level is lowered below static level

pump test made?  Yes  No If yes, by whom?  
gal./min. with ft. drawdown after hrs.  
" " " "  
" " " "  
test 100 gal./min. with — ft. drawdown after 1 hrs.  
an flow g.p.m.

CONSTRUCTION:

Seal—Material used bentonite  
Sealed from land surface to 1.8 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal — sacks  
Where was cement grout placed? Grout was mixed & pumped  
down 1" tremie pipe to bottom of 10" well.  
Type of drive shoe used?  Yes  No Plugs Size: location ft.  
Do any strata contain unusable water?  Yes  No  
Depth of water? depth of strata  
Type of sealing strata off  
Is well gravel packed?  Yes  No Size of gravel:  
Placed from ft. to ft.

(10) LOCATION OF WELL:

County Douglas Driller's well number #2  
WELL SE SE NE 1/4 Section 35 26 T. 22 S R. 13 W W.M.  
Bearing and distance from section or subdivision corner  
Sec 26 SE-SE

(11) WATER LEVEL: Completed well.

Depth at which water was first found 6 ft.  
Static level 6 ft. below land surface. Date 9-27-78  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 4

Depth drilled 87 ft. Depth of completed well 76 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown med-Fine sand	0	77	
Blue GRAY CLAY	77	84	
GRAY Sandstone	84	87	

RECEIVED

JUL 21 2003

WATER RESOURCES DEPT  
SALEM, OREGON

Work started 9-24 19 Completed 9-27 1978  
Date well drilling machine moved off of well 9-27 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] [Signature] Date 10-6-78  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1152

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Aqua-Tech Well Construction Co. Inc.  
(Person, firm or corporation) (Type or print)

Address 868 Delta Dr N.E.

[Signed] David Beach  
(Water Well Contractor)

Contractor's License No. 696 Date 10/12/78, 19