

DEPARTMENT.  
97310  
from the date  
completion.

(Do not write above this line)

OWNER: City of Reedsport  
P.O. Box 358 #3

TYPE OF WORK (check):  
Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

TYPE OF WELL: (4) PROPOSED USE (check):  
Type  Driven  Domestic  Industrial  Municipal   
 Jetted  Irrigation  Test Well  Other   
 Bored

CASING INSTALLED: Threaded  Welded   
0" Diam. from 0 ft. to 7.1 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used  
Number of perforations in by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name Johnson  
PDC Model No.  
No. 4 Slot size 10 Set from 73 ft. to 78 ft.  
No. 4 Slot size 12 Set from 78 ft. to 83 ft.

WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Flow rate: gal./min. with ft. drawdown after hrs.  
m test 100 gal./min. with - ft. drawdown after | hrs.  
Minimum flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

CONSTRUCTION:  
Seal Material used  Bentonite   
Sealed from land surface to  18  ft.  
Diameter of well bore to bottom of seal  10  in.  
Diameter of well bore below seal  6  in.  
Number of sacks of cement used in well seal \_\_\_\_\_ sacks  
Was cement grout placed?  Grout was mixed + pumped through 1" tremie pipe to bottom of 10" Annulus   
Drive shoe used?  Yes  No Plugs Size: location ft.  
Do any strata contain unusable water?  Yes  No  
Depth of water? depth of strata  
Method of sealing strata off  
Well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:  
County  Douglas  Driller's well number  #3   
~~SE~~ SE 1/4 Section  14  T.  22S  R.  13W  W.M.  
Bearing and distance from section or subdivision corner  
 Sec 14 SESE

(11) WATER LEVEL: Completed well.  
Depth at which water was first found  7  ft.  
Static level  7  ft. below land surface. Date  9-29-78   
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing  4   
Depth drilled  92-6  ft. Depth of completed well  83  ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u> Brown med-fine sand </u>	<u> 0 </u>	<u> 84 </u>	
<u> GRAYISH BROWN SAND </u>	<u> 84 </u>	<u> 87 </u>	
<u> GRAY CLAY </u>	<u> 87 </u>	<u> 92-6 </u>	

RECEIVED  
JUL 21 2003

WATER RESOURCES DEPT.  
SALEM, OREGON

Work started  9-27  19  78  Completed  9-29  19  78   
Date well drilling machine moved off of well  9-29  19  78

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed]  [Signature]  Date  10-6-78   
(Drilling Machine Operator)  
Drilling Machine Operator's License No.  1152

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name  Aqua-Tech Well Construction Co Inc.   
(Person, firm or corporation) (Type or print)  
Address  868 Delta Dr. N.E.   
[Signed]  David Beach   
(Water Well Contractor)  
Contractor's License No.  696  Date  10/12/78 , 19