WATER WELL REPORT
STATE OF OREGON

Doug 559

DOUG 559

RECEIVED
NOV 5 1982
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 28s/7w-31

State Permit No. .....

(1) OWNER:

Name Rob Miller
Address P. O. Box 13
City Tenmile, Oregon 97481 State

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☒ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:

Steel ☒ Plastic ☐
Threaded ☐ Welded ☒

6" Diam. from +1 ft. to 19 ft. Gauge .250
..." Diam. from ... ft. to ... ft. Gauge ...

LINER INSTALLED:

..." Diam. from ... ft. to ... ft. Gauge ...

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.
... perforations from ... ft. to ... ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No
Manufacturer's Name ...
Type ... Model No. ...
Diam. ... Slot Size ... Set from ... ft. to ... ft.
Diam. ... Slot Size ... Set from ... ft. to ... ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
could fluctuate " " "
Air test 20 gal./min. with drill stem at 110 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ... ft.

(9) CONSTRUCTION:

Special standards: Yes ☐ No ☒
Well seal—Material used Portland cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
How was cement grout placed? poured through tremie
...
...
Was pump installed? ... Type ... HP ... Depth ... ft.
Was a drive shoe used? ☐ Yes ☒ No Plugs ... Size: location ... ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel: ...
Gravel placed from ... ft. to ... ft.

(10) LOCATION OF WELL:

County Douglas Driller's well number
¼ ¼ Section 31 T. 28s R. 7w W.M.
Tax Lot # Lot Blk Subdivision
Address at well location:

(11) WATER LEVEL: Completed well.

Depth at which water was first found 67 ft.
Static level 20 ft. below land surface. Date 10-20-82
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 110 ft. Depth of completed well 110 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	1	
Brown clay	1	12	
Gray claystone	12	110	

Work started 10-20-82 19 Completed 10-20-82 19
Date well drilling machine moved off of well 10-20-82 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Bob Murphy (Drilling Machine Operator) Date 10-20, 1982
Drilling Machine Operator's License No. 1428

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name John Beck Drilling Company (Person, firm or corporation) (Type or print)
Address 37157 Immigrant Rd., Pleasant Hill, Ore.
[Signed] Casey L. Jones (Water Well Contractor)
Contractor's License No. 559 Date 10-20-82, 19

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690