NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

DOUG 7841

DOUG

007841

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
OCT 5 1973
STATE ENGINEER
SALEM, OREGON

dab

State Well No. 28S/7W-3
State Permit No.

(1) OWNER:
Name GREG G COOPER
Address 726 W. LUELLEN DR.
ROSEBURG OREGON 97470

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 25 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? ☒ Yes ☐ No.
Type of perforator used TORCH
Size of perforations 1/4 in. by 6 in.
60 perforations from 18 ft. to 25 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? MY SELF
Yield: 5 gal./min. with MAX ft. drawdown after 3 hrs.
" " "
" " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 57 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 9 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs NO Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/4 MINUS
Gravel placed from 18 ft. to 24 ft.

(10) LOCATION OF WELL:
County DOUGLAS Driller's well number COOPER #1
NW¼ NE¼ SE¼ Section 3 T. 28 R. 7 W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 18 ft.
Static level 8 ft. below land surface. Date 8-30-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
SOIL SANDY	0	3	
SAND FINE CLAY YELLOW	3	7	
CLAY YELLOW	7	18	8
SAND AND GRAVEL	18	24	8
CLAY STONE GRAY	24	40	8

Work started 8-21 1973 Completed 8-30 1973
Date well drilling machine moved off of well 9-3 1973

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Cecil M Storey (Drilling Machine Operator) Date 9-4, 1973
Drilling Machine Operator's License No. 23

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name CECIL M STOREY (Person, firm or corporation) (Type or print)
Address R.H. BOX 1255 ROSEBURG OREGON
[Signed] Cecil M Storey (Water Well Contractor)
Contractor's License No. 263 Date 9-4, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119