

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED JUN 22 1971 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT STATE OF OREGON

DOUG 008949

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion

(Please type or print)

(Do not write above this line)

State Well No. 29/8W-20

State Permit No.

(1) OWNER: Name Chuck Wildt, Camas Valley School Dist #4, Address Camas Valley Ore

(10) LOCATION OF WELL: County Douglas, Driller's well number, 1/4 Section 20 T. 29S R. 8W W.M., Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check): New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(11) WATER LEVEL: Completed well. Depth at which water was first found 27 ft. Static level 8 ft. below land surface. Date 6-20-71. Artesian pressure lbs. per square inch. Date

(3) TYPE OF WELL: Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored [] (4) PROPOSED USE (check): Domestic [X] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(12) WELL LOG: Diameter of well below casing 6, Depth drilled 62 ft. Depth of completed well 62 ft.

CASING INSTALLED: Threaded [] Welded [X] 6" Diam. from 0 ft. to 20 ft. Gage 1/4

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

PERFORATIONS: Perforated? [] Yes [X] No. Type of perforator used, Size of perforations in. by in., perforations from ft. to ft.

Table with columns: MATERIAL, From, To, SWL. Handwritten entries: Soil 0-4, yellow clay 4-11, Blue clay 11-13, Blue clay stone 13-57, Blue granite 57-62.

(7) SCREENS: Well screen installed? [] Yes [X] No. Manufacturer's Name, Type, Model No., Diam., Slot size, Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level. Was a pump test made? [] Yes [X] No. Yield: gal./min. with ft. drawdown after hrs. Bailer test 20 gal./min. with 27 ft. drawdown after 1 hrs. Artesian flow g.p.m. Temperature of water 40, Depth artesian flow encountered 1 ft.

Work started 6-20 1971 Completed 6-20 1971 Date well drilling machine moved off of well 6-20 1971

(9) CONSTRUCTION: Well seal—Material used Portland Cement, Well sealed from land surface to 18 ft., Diameter of well bore to bottom of seal 9 1/2 in., Diameter of well bore below seal 6 in., Number of sacks of cement used in well seal 4 sacks, Number of sacks of bentonite used in well seal, Brand name of bentonite, Number of pounds of bentonite per 100 gallons of water, Was a drive shoe used? [] Yes [X] No, Plugs, Size: location, ft., Did any strata contain unusable water? [] Yes [X] No, Type of water? Good, depth of strata, Method of sealing strata off, Was well gravel packed? [] Yes [X] No, Size of gravel, Gravel placed from ft. to ft.

Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Raymond B Beck, Date 6-20, 1971, Drilling Machine Operator's License No. 682

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name JOHN T BECK SUTHERLIN, Address R2 Box 8900 ORE, [Signed] John T Beck, Contractor's License No. 436 Date 6-20 1971