

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

DOUG

DOUG 9810 WATER WELL REPORT

RECEIVED

06/27/1972

32S/5W-306

STATE OF OREGON (Please type or print)

STATE ENGINEER SALEM, OREGON

(Do not write above this line)

STATE ENGINEER, SALEM, OREGON 97210 within 30 days from the date of well completion.

(1) OWNER:

Name West Coast Campgrounds Address P.O. 15 Newburg 99 Gladale Ore

(2) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Cable [X] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(10) LOCATION OF WELL:

County Douglas Driller's well number 351 SE 1/4 NW 1/4 Section 30 T. 32S R. 5W W.M. Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 42 ft. Static level 7 ft. below land surface. Date 8-11-72 Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing --- Depth drilled 50 ft. Depth of completed well 50 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Entry: Conglomerate, 0, 50, 7

Work started 8-16 1972 Completed 8-11 1972 Date well drilling machine moved off of well 8-11 1972

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] Joseph E. Coleman Date 9-27, 1972 (Drilling Machine Operator) Drilling Machine Operator's License No. 351

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Name Coleman's Well Drilling (Person, firm or corporation) Address 2060 N.W. Line, Grants Pass [Signed] Joseph E. Coleman (Water Well Contractor) Contractor's License No. 380 Date 9-27, 1972

i) CASING INSTALLED:

Threaded [ ] Welded [X] 6" Diam. from 0 ft. to 50 ft. Gage 1.25

j) PERFORATIONS:

Perforated? [X] Yes [ ] No. Type of perforator used Torch Size of perforations 4 in. by 1/4 in. 12 perforations from 42 ft. to 49 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 13 gal./min. with 25 ft. drawdown after 2 hrs. Artesian flow g.p.m. Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement Well sealed from land surface to 18 ft. Diameter of well bore to bottom of seal 9 in. Diameter of well bore below seal 6 in. Number of sacks of cement used in well seal 3 sacks Number of sacks of bentonite used in well seal Brand name of bentonite Number of pounds of bentonite per 100 gallons of water lbs./100 gals. Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft. Did any strata contain unusable water? [ ] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft.