

RECEIVED

JUL 10 1968

GILL...160

RECEIVED

AUG 14 1968

EN/18-32 D

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

State Well No.

State Permit No.

(1) OWNER:

Name CORPS OF ENGINEERS
Address P.O. Box 741 PASCO, WASH. 99301

(2) LOCATION OF WELL:

County WILLIAM Owner's number, if any 4276
NW 1/4 NW 1/4 Section 32 T. 2N R. 18E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [X] Driven []
Cable [] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

16" Diam. from 0 ft. to 93.7 ft. Gage 375
12" Diam. from 0 ft. to 106.3 ft. Gage 375

(7) PERFORATIONS:

Perforated? [] Yes [X] No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [X] No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? [X] Yes [] No To what depth? 106 ft.
Material used in seal- CEMENT GROUT
Did any strata contain unusable water? [] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 32 ft. below land surface Date 6/5/68
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Date 19

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? STRASSER
Yield: 340 gal./min. with 78 ft. drawdown after 48 hrs.
225 " 42.5 " 15 "
148 " 23 " 9 "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 61 Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well 12 inches.
Depth drilled 273 ft. Depth of completed well 273 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include SANDY TOP SOIL, SAND, CEMENTED GRAVEL, BOULDERS, SILT AND SAND, GRAVEL AND BOULDERS, etc.

Work started APR 7 1968 Completed JUNE 19 1968

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R.J. STRASSER DRILLING CO
(Person, firm, or corporation) (Type or print)

Address 8110 SE SUNSET LAVE PORTLAND ORE

Driller's well number 564, 395, AND 175

[Signed] Robert L. Strasser
(Well Driller)

License No. 10 Date JULY 9, 1968