

GILL 192

RECEIVED

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE OF OREGON ENGINEER

State Well No. 3/21-19

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

(Please type or print) PERMIT OREGON Permit No.

(1) OWNER:

Name CITY OF CONDON Address

(2) LOCATION OF WELL:

County WILLIAM Driller's well number 1/4 Section T. R. W.M. Bearing and distance from section or subdivision corner SEC-19-T-3-S R-21 LWM

(3) TYPE OF WORK (check):

Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [X] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 40 ft. Gage 250 10" Diam. from 0 ft. to 55 ft. Gage 250 8" Diam. from 50 ft. to 90 ft. Gage 250

(7) PERFORATIONS:

Perforated? [X] Yes [ ] No Type of perforator used PUTTING TORCH Size of perforations # in. by 3 in. 300 perforations from 90 ft. to 90 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No Manufacturer's Name Model No. L. n. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT-DRILLED Depth of seal 30 ft. Was a packer used? NO Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [X] Yes [ ] No Depth 5.3 Was a drive shoe used? [X] Yes [ ] No 10" Was well gravel packed? [ ] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 17 ft. below land surface Date 5-9-67 Artesian pressure NONE lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [ ] No If yes, by whom? JACKSON Yield: 58 gal./min. with 26 ft. drawdown after 6 hrs. 78 " 28 " 12 " Bailer test 50 gal./min. with NO ft. drawdown after 2 hrs. Artesian flow g.p.m. Date Temperature of water 52 Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG:

Diameter of well below casing Cased to 307 ft. Depth drilled 90 ft. Depth of completed well 90 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include OVER BURDEN, BLACK SANDY CLAY, BLACK SAND, WATER BEARING CONG., BLUE CLAY, VOLCANIC ASH, WATER BEARING BLACK SAND, HARD BLACK BASALT.

Work started 5-1 1967 Completed 5-9 1967 Date well drilling machine moved off of well 5-9 1967

(13) PUMP:

Manufacturer's Name JAEZZI Type: 5 step H.P. 5

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME JACKSON DRILLING SERV. Address REDMOND ORE. BOX 1520

Drilling Machine Operator's License No. 370

[Signed] Thomas Jackson (Water Well Contractor)

Contractor's License No. 442 Date 5-9 1967