

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON

within 30 days from the date
of well completion

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

STATE ENGINEER

SALEM, OREGON

GILL-210

State Well No. 5/21-28

28cd6

State Permit No. G 5120

(1) OWNER:

Name Chester R. Dyer
Address Mayville Ave.

(2) TYPE OF WORK (check):

New Well ☐ Deepening ☐ Reconditioning ☒ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☒ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒

12" Diam. from 0 ft. to 18 ft. Gage 250
10" Diam. from 0 ft. to 220 ft. Gage 250
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations	in. by	in.
perforations from ft. to ft.		
perforations from ft. to ft.		
perforations from ft. to ft.		
perforations from ft. to ft.		
perforations from ft. to ft.		

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 225 ft. below land surface Date Sept 29/69
Artesian pressure None lbs. per square inch Date Sept 29/69

(9) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Owner
Yield: 180 gal./min. with 75 ft. drawdown after 8 hrs.
" " " "

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow None g.p.m. Date Sept 29 69
Temperature of water 48 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Bentonite & cement
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Gilliam Driller's well number
1/4 1/4 Section 26 T. 21E. 58 W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 9" 420' 6" 580

Depth drilled 580 ft. Depth of completed well 573 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Existing hole	320	320	225
Black Basalt	320	410	225
Fractured Basalt +	410	420	225
Granite			
Black Basalt	420	575	225
Fractured Basalt	573	581	225
9" hole to 420'			
6" hole from 420' to 580			

Work started Sept 2 1968 Completed Sept 29 1969

Date well drilling machine moved off of well Sept 29 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] C.H. Brandt Date Oct 10, 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 189

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Brandt Drilling Co. (Person, firm or corporation) (Type or print)

Address Box 233 Pineville Ore

[Signed] C.H. Brandt (Water Well Contractor)

Contractor's License No. 283 Date Oct 6, 1969