

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 JUN 18 1968
within 30 days from the date of well completion.

STATE ENGINEER
SALEM, OREGON

GILL...211...

WELL REPORT

STATE OF OREGON

(Please type or print)
(Do not write above this line)

State Well No. 5/21-28cbb

State Permit No.

G5120

(1) OWNER:

Name CHESTER R. DYER
Address MAXVILLE ORE

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☒ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☐

" Diam. from TEMP to ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☐ No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☐ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level ft. below land surface Date
ian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? J.L. DAY
old: 75 gal./min. with 10 ft. drawdown after 12 hrs.
TEST PUMPED AT 240 FT

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(10) CONSTRUCTION:

Well seal—Material used NOT SEALED
Depth of seal ft.
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? ☐ Yes ☐ No Depth
Was a drive shoe used? ☐ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County GILLIAM Driller's well number
1/4 1/4 Section 28 T.55-S R. 21 E W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 8 1/2 to 3 1/2

Depth drilled 350 ft. Depth of completed well 350 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
OVERBURDEN	0	3	
SAND STONE	3	130	
WATER BEARING SAND	130	250	
TEST PUMPED AT 240 FT			
YIELD ABOUT 75 GPM.			
HARD BLACK BASALT			
From 250 350 140			
THIS WELL HAS			
A 12" STARTING PIPE WITH			
A STEEL LID WELDED ON IT			
MR. DYER WILL HAVE THAT			
HAS A HAMMER DRILL TO			
FINISH THE WELL TO SEE IF			
THE WATER WILL BE ARTESIAN			

Work started 12-15 1967 Completed NOT COM 1968
Date well drilling machine moved off of well MAR 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Thomas Jackson Date 6-16, 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 370

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME JACKSON DRILLING SERV
(Person, firm or corporation) (Type or print)

Address REDMOND ORE

[Signed] Thomas Jackson
(Water Well Contractor)

Contractor's License No. 442 Date 6-16, 1968