

GILL.....89

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED
OCT 13 1969
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 11225-10 dbd
State Permit No.

State Obs. Well 1040

(1) OWNER:

Name RAYMOND AND HANNA HEIM BIDNER
Address BOX 82 CIRCLE @ RANCH FONE, ONE

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Driven []
Cable [] Jetted []
[] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

CASING INSTALLED:

18" Diam. from 0 ft. to 250 ft. Gage 277
Threaded [] Welded [X]

PERFORATIONS:

Perforated? [] Yes [X] No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 136 ft. below land surface Date 9-5-69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom?
Flow: 2800 gal./min. with 1800" at 390-1-24 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 62 Was a chemical analysis made? [] Yes [X] No

(10) CONSTRUCTION:

Well seal-Material used CEMENTED
Depth of seal 48 ft. GREY BASALT ft.
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [] Yes [X] No
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Gilliam Driller's well number
1/4 1/4 Section 10 T. 45. R. 22 W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 16
Depth drilled 414 ft. Depth of completed well 395 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: BROWN SANDY TOP SOIL, BLUE BASALT, HONEY COMBED, BROWN SANDY SHALE, BEA ENAVEL, GREY BASALT - HARD, GREY BASALT w/ RED/BROWN/SHALE, GREY BASALT, FRACTURED, BLUE BASALT / RED HONEY COMB, GREY BASALT - HONEY COMB, GREY BASALT - HARD, GREY BASALT, w/ BENTONITE, GREY BASALT - HARD, BROWN CLAY - RED HONEY COMB, GREY BASALT HARD.

Just water encountered at about 200 ft.

Work started 6-15 1969 Completed 9-12-1969
Date well drilling machine moved off of well 9-12-1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Rudd W. Davis Date 10/1, 1969
(Drilling Machine Operator)
Drilling Machine Operator's License No. 147

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Rudd W. Davis (Person, firm or corporation) (Type or print)
Address R. 1, Box 162 m-f, One,
[Signed] Rudd W. Davis (Water Well Contractor)
Contractor's License No. 159 Date 10/1, 1969