

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

GRAN... 166

State Well No. 11/29-13

State Permit No.

(1) OWNER:

Name Alva Wright
Address For Ore

(2) LOCATION OF WELL:

County Grant Driller's well number
1/4 Section 13 T. 11S R. 29E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 38 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations	in. by	in.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.
perforations from	ft. to	ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
vpe Model No.
m. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Commercial Mud
Depth of seal 38 ft. Was a packer used? no
Diameter of well bore to bottom of seal 8 1/2 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level Ground level ft. below land surface Date 7/13, '66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Columbia pump
Yield: 200 gal./min. with 140 ft. drawdown after 6 hrs.

Baller test	gal./min. with	ft. drawdown after	hrs.
Artesian flow	g.p.m.		Date

Temperature of water 48 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 230 ft. Depth of completed well 230 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	2
Blue clay	2	16
Grey clay and sand	16	32
Sand & stone coarse	32	140
Sand & stone very coarse with lots of water	140	170
It returned and deepened this well 60 more ft. This additional footage was all sand stone.	170	230

Work started 7/10 1966 Completed 7/12 1966
Date well drilling machine moved off of well 7/13 1966

(13) PUMP:

Manufacturer's Name not installed yet 1966
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ROY T FRENCH (Type or print)
Address 1015 NW Roger Bendleton Ave

Drilling Machine Operator's License No. 209

[Signed] Roy T French (Water Well Contractor)

Contractor's License No. 107 Date Aug 16, 1966