

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

GRAN...178

G-3694

State Well No.

11/29-35H

State Permit No.

(1) OWNER:

Name Nicholas Bonifacich
Address Fry Ave

(2) LOCATION OF WELL:

County Grant Driller's well number
1/4 Section 11 T. 29 R. 2 W.M.
Bearing and distance from section or subdivision corner

See 35

(3) TYPE OF WORK (check):

W Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 25 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☐ No

Manufacturer's Name
Type Model No.
am. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Commercial mud
Depth of seal 25 ft. Was a packer used?
Diameter of well bore to bottom of seal 8.5 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 2 ft above ground ft. below land surface Date
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" air tested " "
" approx 75 min " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow 3 g.p.m. Date Aug 8, 1966
Temperature of water 54.9 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well below casing 6 in

Depth drilled 200 ft. Depth of completed well 200 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	4
Clay and boulders	4	18
broken clay	18	36
sand stone	36	85
black basalt with		
quartz seams	85	140
gray basalt hard	14	178
red rock porous	178	200

small amount of water
at 140 ft. not more than
one gal per min
main water 178 - to 200
was stopped at bottom
red rock.

Work started Aug 5 19 66 Completed Aug 8 19 66
Date well drilling machine moved off of well Aug 8 19 66

(13) PUMP:

Manufacturer's Name none
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ROY-T. FRENCH
(Person, firm or corporation) (Type or print)

Address 1015 S.W. Roger Penetration Ave

Drilling Machine Operator's License No. 209

[Signed] Roy T. French
(Water Well Contractor)

Contractor's License No. 107 Date Oct 4, 19 66