

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

(1) OWNER:

Name Frank Mc Curt
Address Fort Gre

(2) LOCATION OF WELL:

County Grant Driller's well number
 ¼ ¼ Section 6 T. 11S. R. 30E. W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
 abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐ Rotary ☒ Driven ☐
Irrigation ☒ Test Well ☐ Other ☐ Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(5) TYPE OF WELL:

(6) CASING INSTALLED: Threaded ☐ Welded ☒

8" Diam. from 0 ft. to 20 ft. Gage 250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations	in.	by	in.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name Model No.

Length Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Comm Mud
Depth of seal 0 to 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth _____
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 12 ft. below land surface Date 8, 20, 66
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs

" air tested approx 90 gal min
" " " "

Bailer test	gal./min. with	ft. drawdown after	hrs
-------------	----------------	--------------------	-----

Artesian flow	g.p.m.	Date
---------------	--------	------

Temperature of water 46 Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:

Diameter of well below casing 8 in.

Depth drilled 120 ft. Depth of completed well 120 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

[illegible]

Work started	8, 20,	19 66	Completed	8, 20,	19 66
Date well drilling machine moved off of well	8, 21,	19 66			

(13) PUMP:

Manufacturer's Name none

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ROY T FRENCH
(Person, firm or corporation) (Type or print)
Address 1015 S.W. Frazier Bendleton Ore

Drilling Machine Operator's License No. 209

[Signed] Roy F. French
(Water Well Contractor)

Contractor's License No. 107 Date 10, 8, 1966