

RECEIVED

1966 WATER WELL REPORT

GRAN 77

State Well No. 11130-6 J

STATE ENGINEER, SALEM, OREGON 97301 STATE ENGINEER, STATE OF OREGON
(Please type or print)

G-3808

State Permit No.

(1) OWNER: Frank Mc. Girt
Name Frank Mc. Girt
Address Box 96

County Grant Driller's well number _____
 1/4 6 1/4 Section 6 T. 11 S. R. 30 ^E W.M.
 Bearing and distance from section or subdivision corner _____

Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
Abandonment, describe material and procedure in Item 12.

Domestic ☐ Industrial ☐ Municipal ☐ Rotary ☐ Driven ☐
Irrigation ☒ Test Well ☐ Other ☐ Cable ☐ Jetted ☐
Dug ☐ Bored ☐

Threaded ☐ Welded ☐
 20 ft. Gage 250

Size of perforations	in.	by	in.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.
perforations from	ft.	to	ft.

Manufacturer's Name Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

Well seal—Material used in seal Comm. Mud
 Depth of seal 0-20 ft. Was a packer used?
 Diameter of well bore to bottom of seal 10 in.
 Were any loose strata cemented off? ☐ Yes ☒ No Depth
 Was a drive shoe used? ☐ Yes ☒ No
 Was well gravel packed? ☐ Yes ☒ No Size of gravel:
 Gravel placed from ft. to ft.
 Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
 Method of sealing strata off

Static level 8 ft. below land surface Date 9, 19, 66
Artesian pressure _____ lbs. per square inch Date _____

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield:	gal./min. with	ft. drawdown after	hrs
"	<i>Air tested</i>	<i>30 gal min</i>	"
"	"	"	"

Bailer test	gal./min. with	ft. drawdown after	hrs
-------------	----------------	--------------------	-----

Artesian flow g.p.m. Date _____

Temperature of water 16° Was a chemical analysis made? ☐ Yes ☒ No

Diameter of well below casing 8 in

Depth drilled 140 ft. Depth of completed well 140 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	4
yellow clay fine	4	32
red clay fine turf	32	105
red clay and fine gravel	105	140

All water was reached in the gravel from 105 - 140 ft.

Work started 8/19, 19 66 Completed 8/19, 19 66
Date well drilling machine moved off of well 8/19, 19 66

(13) PUMP:

Manufacturer's Name *none*
Type: **H.P.**

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME ROY-T-FRENCH
(Person, firm or corporation) (Type separately)
Address 1015 S Wagon Bendition Ave

Drilling Machine Operator's License No. 209

[Signed] Roy French
(Water Well Contractor)

Contractor's License No. 107 Date 10/8, 1966