

OCT 21 1960

OBSERVATION WELL GRAN 214

12/26-34 J(1)

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT GRAN 214 STATE OF OREGON

State Well No. State Permit No.

(1) OWNER:

Name Dayville Cemetery District Address Dayville Oregon

(2) LOCATION OF WELL:

County Grant Owner's number, if any- 34 T. 12 R. 26 E W.M. Bearing and distance from section or subdivision corner N 1/2 NE 1/4 SE 1/4

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [X] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 7 ft. Gage 28 + B 6" Diam. from 0 ft. to 22.2 ft. Gage 19 + B

(7) PERFORATIONS:

Perforated? [] Yes [X] No Type of perforator used SIZE of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [X] No Manufacturer's Name Type Model No. 6 in. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [X] Yes [] No To what depth? 7 ft. Material used in seal- 8" casing Did any strata contain unusable water? [] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 15.5 ft. below land surface Date 4 Oct 60 Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] George O'Mannell (Owner) Date Oct 4 1960 Chairman Cemetery District

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 5 gal./min. with 3.5 ft. drawdown after 2 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well 6 inches. Depth drilled 22.4 ft. Depth of completed well 22.4 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Over burden (0-10), Gravel (10-35), Clay (35-197), Sand & tone (197-224)

Work started 19 Sept 19 60 Completed 12 Oct 19 60

(13) PUMP:

Manufacturer's Name Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME O.E. Hurst (Person, firm, or corporation) (Type or print)

Address 836 S. 12th St Redmond Oregon

Driller's well number

[Signed] O.E. Hurst (Well Driller)

License No. 72 Date Oct 4 1960



Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301
(503) 986-0900
www.oregon.gov/owrd

Application for Well ID Number

RECEIVED

MAR 9 2023

OWRD

Do not complete if the well already has a Well Identification Number.

I. OWNER INFORMATION

Current Owner Name (please print): Dayville cemetery
Mailing Address: PO Box 31
City, State, Zip: Dayville OR 97825
Mail Well ID to: SAME AS ABOVE In Care Of (C/O) No packet necessary
Name & Address: Tag attached by well inspector
City, State, Zip: _____

II. WELL LOCATION INFORMATION (Please fill out as completely as possible)

Township: 12 (North/South) Range: 26 (East/West) Section: 34 NE 1/4 of the SE 1/4
Tax Lot (usually last 3-5 numbers of Tax Map #): 3501 County Grant
GPS Coordinates: 44.48309013, -119.57469631
Street Address of Well, City: Hwy 26
If the property had a different street address in the past: _____

III. GENERAL WELL INFORMATION (Please fill out as completely as possible, AND attach copy of Well Report, if available)

Use of Well (domestic, irrigation, commercial, industrial, monitoring): Municipal
Date Well Constructed (or property built): 10/12/1960 Total Well Depth: 478' Casing Diameter: 8"
Owner at time the well was constructed (if known): Dayville cemetery Well Report # (if known): GRAN 214
Other Information: _____

SUBMITTED BY (please print): Don Sufilippo (well inspector)
PHONE: _____ EMAIL &/or FAX: _____

To send the completed application, you may MAIL it to: Oregon Water Resources Dept. 725 Summer St NE, Suite A, Salem, Oregon 97301.
Or EMAIL the completed PDF form to: Ladeena.K.Ashley@water.oregon.gov, or FAX it to: (503) 986-0902.

For Official Use Only by the Oregon Water Resources Department:

Received Date:
3-9-2023

Well Report Number:
GRAN 214

Well Identification #:
L-13731