

Well # 3 RECEIVED

13
20/29-22

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

AUG 29 1962

GRANT 301... STATE OF OREGON STATE ENGINEER (Please type or print)

State Well No. State Permit No.

(1) OWNER:

Name John Course
Address Mt Vernon Oregon

(2) LOCATION OF WELL:

County GRANT Driller's well number
SW 1/4 SE 1/4 Section 22 T. 30 R. 29 E. W. M.
Bearing and distance from section or subdivision corner

well # 3

SE NW

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
16" Diam. from -1 ft. to 50 ft. Gage 4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Mills
Size of perforations 3/8 in. by 4 in.
240 perforations from 20' ft. to 49' ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CLAY
Depth of seal 17' ft. Was a packer used? SAND
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 22' ft. below land surface Date 8-8-62
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? DRILLER
Yield: 540 gal./min. with 130 ft. drawdown after 4 hrs.
" " " " "
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 56° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 15"
Depth drilled 245' ft. Depth of completed well 230' ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SOIL SANDY	0	6
GRAVEL CEMENTED	6	30
CLAY BROWN	20	34
GRAVEL MEDIUM	24	48
CLAY BROWN	48	105
CLAY STRIPS GRAVEL	105	170
CLAY YELLOW	170	205
CLAY STRIPS MEDIUM		
GRAVEL	205	235
CLAY YELLOW	235	245

Work started 6-25 1962 Completed 8-8 1962
Date well drilling machine moved off of well 8-8 1962

(13) PUMP:

Manufacturer's Name NO PUMP yet
Type:

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Holloway Drilling Co
(Person, firm or corporation) (Type or print)
Address ONTARIO

Drilling Machine Operator's License No. 101

[Signed] Max Holloway
(Water Well Contractor)

Contractor's License No. 16 Date 8-28, 1962