

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

366
GRAN. State Well No. 135/30E-30 CA

State Permit No.

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

(1) OWNER:

Name Francis L MARCIEL
Address MT VERNON O.R. R.R. W

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded

2" Diam. from 1 ft. to 10.0 ft. Gage 350
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?

1: 500 gal./min. with 80 ft. drawdown after 3 hrs.

compressor " " "

Baller test gal./min. with ft. drawdown after hrs.

van flow 20 g.p.m.

Temperature of water 56 Depth artesian flow encountered 100 ft.

(9) CONSTRUCTION:

Well seal—Material used Cement

Well sealed from land surface to 95 ft.

Diameter of well bore to bottom of seal 15 in.

Diameter of well bore below seal 10 in.

Number of sacks of cement used in well seal 85 sacks

How was cement grout placed? Pumped

Through Grout Pipe

Was a drive shoe used? Yes No Plugs Size: location ft.

Did any strata contain unusable water? Yes No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? Yes No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Grant Driller's well number F-80-5
NE 1/4 SW 1/4 Section 30 T. 135 R. R 30E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 100 ft.

Static level 6' ft. below land surface. Date 3-19-80

Artesian pressure 0 lbs. per square inch. Date 3-19-80

(12) WELL LOG:

Diameter of well below casing 10

Depth drilled 160 ft. Depth of completed well 140 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL Brn.	0	2	
Gravel med	2	15	
Clay Red med	15	35	
CLAY TAN med	35	80	
SAND STONE Grey Hard	80	88	80
SANDY CLAY TAN med	88	100	
CLAY Red med	100	110	0
Gravel Blk. med	110	120	0
SAND STONE Med	120	140	
SAND STONE Grey Hard	140	150	
CLAY TAN med	150	160	

RECEIVED

APR 7 1980

WATER RESOURCES DEPT
SALEM, OREGON

Work started 3-7 1980 Completed 3-19- 1980

Date well drilling machine moved off of well 3-19 1980

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Francis R. Phelps, Date 3-23, 1980
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1185

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Jobe Drilling Inc.
(Person, firm or corporation) (Type or print)

Address Traverse City, Oregon

[Signed] Bob Jobe
(Water Well Contractor)

Contractor's License No. 582 Date 31 Mar, 1980