

STATE OF OREGON
WATER WELL REPORT
 (as required by ORS 537.765)

RECEIVED
 MAR 5 1986
 GRAN. 78.4
 2/28/1986
 RECEIVED
 OFFICE

1105/31E-35cb
 Grant Co

WATER RESOURCES DEPT

(1) **OWNER:**
 Name Hines Lumber Co.
 Address _____
 City Seneca State Ore Zip _____
 Owner's Well Number _____

LOCATION OF WELL by legal description:

County _____ Latitude _____ Longitude _____
 Township 163 N or S, Range 30 E or W, WM.
 Section 35 SW 1/4 NW 1/4
 Tax Lot _____ Lot _____ Block _____ Subdivision _____
 Street Address of Well (or nearest address) _____

(2) **TYPE OF WORK:**
 New Well Deepen Recondition Abandon

(3) **DRILL METHOD:**
 Rotary Air Rotary Mud Cable Other

(4) **PROPOSED USE:**
 Domestic Community Industrial Irrigation
 Thermal Injection Other _____

(10) **STATIC WATER LEVEL:**
32 ft. below land surface. Date _____
 Artesian pressure _____ lb. per square inch. Date _____

(5) **BORE HOLE CONSTRUCTION:**
 Depth of Completed Well 160 ft.
 Special Standards date of approval _____

(11) **WELL LOG:** Ground elevation _____

HOLE		SEAL		Amount sacks or pounds
Diameter	From To	Material	From To	
2"	0' 19'	Concrete	0' 19'	

Material	From	To	WB?	SWL
Top Soil	0	3		
Clay, tan	3	8		
Clay, Blue/Sand	8	10		
Clay, Brown + Red	10	80		
Shale, Blue	80	90		
Sandstone, Gray	90	95	WB	37
Course Gravel	95	120		
Shale + Clay - Blue	120	140		
Sand	140	148		
Sand / Clay	148	160		

How was seal placed? Method A B C D E
 Other _____
 Backfill placed from _____ ft. to _____ ft. Material _____
 Gravel placed from _____ ft. to _____ ft. Size of gravel _____

(6) **CASING/LINER:**

Casing/Liner	Diameter	From	To	Gauge	Steel		Plastic		Welded		Threaded	
					✓		✓		✓		✓	
Casing:	16"	0	19	2.50	✓				✓			
	12"	0	160	2.50	✓				✓			
Liner:												

Final location of shoe(s) _____

(7) **PERFORATIONS/SCREENS:**

Perforations Method Mill Slot
 Screens Type _____ Material _____

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
80'	160'	1/8"	960			✓	

Date started 19 July 1978 completed 1 Aug 1978

(8) **WELL TESTS: Minimum testing time is 1 hour**
 Pump Bailor Air Flowing Artesian
 Yield gal/min 80 Pumping level _____ Drill stem at 140' Time 1/2 hr 1 hr

(unbonded) Water Well Constructor Certification:
 I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Temperature of water 50 Depth Artesian Flow Found _____
 Was a water analysis done? Yes By whom _____
 Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other _____
 Depth of strata: _____

Signed Bond Jabe Date 27 Feb 1986

(bonded) Water Well Constructor Certification:
 I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Bond Jabe Date 27 Feb 1986

Company Water Drilling Co. Job No. _____