

RECEIVED
 FEB 27 1961
 STATE ENGINEER
 SALEM, OREGON

WATER WELL REPORT
 STATE OF OREGON

114 HARN

State Well No. 22/31-320
 State Permit No. G.1798

File Original and
 First Copy with the
 STATE ENGINEER,
 SALEM, OREGON

(1) OWNER:
 Name HARRY PON
 Address BURNS OREGON

(2) LOCATION OF WELL:
 County HARNEY Owner's number, if any #1
 NW 1/4 NW 1/4 Section 323 T.22 S. R. 31 E W.M.
 Bearing and distance from section or subdivision corner
 Well is located 500 yds. of
 house occupied by Art
 Doman Foreman for Harry
 Pon

(3) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):
 Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:
 Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:
 Threaded Welded
 14" Diam. from -1 ft. to 226 ft. Gage 4"
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS:
 Perforated? Yes No
 Type of perforator used STAR
 SIZE of perforations 1 in. by 3/16 in.
 4560 perforations from 36 ft. to 226 ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(8) SCREENS:
 Well screen installed Yes No
 Manufacturer's Name
 Type Model No.
 Diam. Slot size Set from ft. to ft.
 Slot size Set from ft. to ft.

(9) CONSTRUCTION:
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.
 Was a surface seal provided? Yes No To what depth? ft.
 Material used in seal—
 Did any strata contain unusable water? Yes No
 Type of water? Depth of strata
 Method of sealing strata off

(10) WATER LEVELS:
 Static level 8' ft. below land surface Date Feb 14-61
 Artesian pressure lbs. per square inch Date
 Log Accepted by: Mr Pon in California
 [Signed] not available at Present, 19
 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? -
 Yield: 540 gal./min. with 132 ft. drawdown after 8 hrs.
 " " " " "
 " " " " "
 " " " " "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date
 Temperature of water 57 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 14 inches.
 Depth drilled 260 ft. Depth of completed well 260 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	18
Clay + Gravel	18	74
Blue shale	74	84
Sand + Gravel	84	112
Blue shale	112	141
Sand Rock	141	153
Sand + Gravel	153	173
Grey Clay + Gravel	173	205
Red Clay	205	208
Red Cinders	208	212
Porous Red Rock	212	226
Hard Red Rock	226	237
Hard Black Rock	237	248
Soft Rock	248	250
Hard Rock	250	260

Reduced to 10" hole at 225'

Work started Jan 24 1961 Completed Feb 14 1961

(13) PUMP:
 Manufacturer's Name No Pump yet
 Type:

Well Driller's Statement:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 NAME Holloway Drilling Co
 (Person, firm, or corporation) (Type or print)
 Address ONTARIO ORE
 Driller's well number #
 [Signed] Max Holloway
 (Well Driller)
 License No. 16 Date Feb 25, 1961