## NOTICE TO WATER WELL CONTRACTOR The original and first copy

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date within 30 days from the date?

of well completion.

of this report are to be filed with the

## WATER WELL REPORT

(Please type or print)
(Do not write above this line)

State Well No.

State Permit No.

(1) OWNER:	(11) LOCATION OF WELL:	
Name Lester Thompson ON	County Harney Driller's well number	
Address Princeton, Oregon	14 . 14 Section 13 T.26 S R. 33 E	W.M
(0) TYPE OF WORK (1.1)	Bearing and distance from section or subdivision corner	
(2) TYPE OF WORK (check):	2245 Ft. North of SE corner section 13	<u></u>
New Well Deepening Reconditioning N Abandon		
If abandonment, describe material and procedure in Item 12.	1.4	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing 12	
Rotary Driven Domestic Industrial Municipal Domestic		
Dug ☐ Bored ☐ Irrigation X Test Well ☐ Other ☐	The property of completed well —	ft
CASING INSTALLED: Threaded   Welded	Formation: Describe color, texture, grain size and structure of mand show thickness and nature of each stratum and aquifer pene	iterials etrated
"Diam. fromft. toft. Gage	with at least one entry for each change of formation. Report each	change
"Diam. fromft. toft. Gage	in position of Static Water Level as drilling proceeds. Note drilling	
"Diam. fromft. toft. Gage	MATERIAL From To	SWL
PERFORATIONS: Perforated?   Yes   No.	This well was caved in to 80 ft.	
Type of perforator used		
Size of perforations in. by in.	Set screen to 96 ft.	
perforations fromft. toft.		
perforations from ft. to ft.		
perforations fromft. toft.		
perforations from ft. to ft.		
perforations fromft. toft.		
(7) SCOPENC.		
(7) SCREENS: Well screen installed? X Yes □ No		
Manufacturer's Name Torch cut 76 ft total	4	*
Type 12 in. pipe Model No.		
25 Slot \$iz x10" Set from 42 ft. to 47 ft.		
Dism138 Slotfsize x1011. Set from65 ft. to9.6		
(8) WATER LEVEL: Completed well.		
Static level 33 ft. below land surface Date 3/10/68		-
Arresian pressure lbs. per square inch Date		7.4
		•
(9) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made Wy Yes   No If yes, by whom? Driller		. 1 =
1: 880 gal./min. with 19 ft. drawdown after 3 hrs.	Work started 2/20/68 19 Completed 3/10/68	19
" "	Date well drilling machine moved off of well 3/12/68	19
" " " " "	Drilling Machine Operator's Certification:	
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my direct supervision.	Mate-
	rials used and information reported above are true to my knowledge and belief,	/ best
, and special distriction of the second seco	7 7	
Temperature of water 560 Was a chemical analysis made?   Yes No	[Signed] AGU / Johnson Date 4/8/68, (Drilling Machine Operator)	19
(10) CONSTRUCTION:		
Well seal—Material used	Drilling Machine Operator's License No. 128	
Depth of seal ft.	Water Well Contractor's Certification:	
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this rep	ort ic
Were any loose strata cemented off?   Yes   No Depth	true to the best of my knowledge and belief.	O1 0 13
Was a drive shoe used?  Yes  No	NAME EL. Koeneman Drilling  (Person, firm or corporation) (Type or print)	
Did any strata contain unusable water?   Yes No		
Type of water? depth of strata	Address Box 327 Burns, Oregon 97720	•••••
	El - 1/2	
Method of sealing strata off	[Signed] Colga d- Homeman	
Was well gravel packed? ☐ Yes ☐ No Size of gravel;	(Water Well Contractor)	, .
Gravel placed from ft. to ft.	Contractor's License No. 323 Date June 1968 , 19	<b>9</b>