NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
NOV - 3 1975
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 27S/30E-1
State Permit No.

1451 Horn

(1) OWNER:
Name Ronald Shelley
Address Princeton, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☒

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from plus 1 ft. to 29 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " no noticeable "
Bailer test 30 gal./min. with ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used bentonite slurry
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 0 sacks
Number of sacks of bentonite used in well seal about 100# ~~sacks~~
Brand name of bentonite bulk
Number of pounds of bentonite per 100 gallons of water 1000 lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Harney Driller's well number
NW¼ NE ¼ Section 1 T. 27 R. 30E W.M.
Bearing and distance from section or subdivision corner
50'E of N-S sec.line& 1390'N of EW line (center lines)

(11) WATER LEVEL: Completed well.
Depth at which water was first found 35 ft.
Static level 42 ft. below land surface. Date 6-16-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 73 ft. Depth of completed well 73 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
brown topsoil	0	1	
hardpan	1	7	
brown clay w/occasional			
streaks of black cinders	7	25	
brown claystone	25	30	
streaks of black cinders			
~~and brown clay; water~~	30	73	42

Work started 6-12 1975 Completed 6-16 1975
Date well drilling machine moved off of well 6-20 1975

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Forest Skinner Date 10-31-, 1975
(Drilling Machine Operator)
Drilling Machine Operator's License No. 10

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name SKINNER & SONS
(Person, firm or corporation) (Type or print)
Address CRANE ORE.
[Signed] Catherine Skinner
(Water Well Contractor)
Contractor's License No. 372 Date 10-31, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119