NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

## RECEIVED

WATER WELL REPORT JUL 1 5 1974 State Well No. 235/30E-14 dd

SP\*45656-119

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON

(Please type or print) STATE ENGINEER

On not write above this lineSALEM, OREGON

100

	7-1-
(1) OWNER:	(10) LOCATION OF WELL:
Name William Grandstaff	County Harney Driller's well number
Address 504 N. Saginaw Hines, Ore.	SE 1/4 SE 1/4 Section 14 T. 23S R. 30 E W.M.
	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	150' N of S section line & 490'
New Well 🛴 Deepening 🗌 Reconditioning 🗍 Abandon 🗎	W of E line
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 86 ft.
Rotary Driven Domestic Industrial Municipal	Static level 20 ff. below land surface. Date 5-25-74
Cable	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded Welded 5  6 "Diam. from plus 1 ft. to 81 ft. Gage 250  "Diam. from ft. to ft. Gage "Diam. from ft. to ft. Gage  PERFORATIONS: Perforated? Yes XXNo.	(12) WELL LOG: Diameter of well below casing 6.11.  Depth drilled 141 ft. Depth of completed well 141 ft.  Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	brown topsoil 0 3
perforations from ft. to ft.	brown clay 3 24
perforations from ft, to ft.	brown clay w/ st/reaks
perforations fromft. toft.	of broken rock 24 86
(7) SCREENS: Well screen installed? ☐ Yes ☒ No	sandstonewater 86 141 26
(7) SUREENS: Well screen installed? ☐ Yes ☒ No Manufacturer's Name	
Type Model No	
Diam. Slot size Set from ft. to ft.	
Diam Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes 전 No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
" " "	
" " "	
Baller test 70 gal./min. with ft. drawdown after 1 hrs.	
And a star Clause	
perature of water Depth artesian flow encountered ft.	Work started 5-20 1974 Completed 5-25 1977
	Date well drilling machine moved off of well 5-27 1974
(9) CONSTRUCTION:  well seal-Material used bentonite slurry	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision.  Materials used and information reported above are true to my best knowledge and belief.  [Signed] OLLAS Decree 6 - 6, 19 74  (Drilling Machine Operator)  Drilling Machine Operator's License No
Brand name of bentonite bulk-no brand name	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons of water $1000$ lbs./100 gals.	This well was drilled under my jurisdiction and this report is
or water	true to the best of my knowledge and belief.  Name Skinner & Sons
Did any strata contain unusable water?  Yes No	Name SKIMMET SOMS  (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address Crane, Oregon 97732
Method of sealing strata off	bothering I bearing
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	[Signed] William Sharman (Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 372 Date June 6, 1974