
WATER WELL REPORT

, STATE OF OREGON



RECEIVED

APR 16 1981 State Well No.

335/30E-356

WATER RESOURCES DEPTermit No. ... SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:		
Name Norman C. Strawn (Strawns Mobil Home Park)	County Harney Driller's well number One		
Address Burns, Bend Star Rt.	SE 4 NE 4 Section 35 T. 233 R.	30Ew.m.	
City Hines, Oregon 97738 State	Tax Lot # Lot Blk	Subdivision	
(2) TYPE OF WORK (check):	Address at well location: Strawas Mobil Home Park		
New Well ☑ Deepening □ Reconditioning □ Abandon □	(11) WATER LEVEL: Completed well		
If abandonment, describe material and procedure in Item 12.	± ±.	_	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 07 ft. Static level 05 ft. below land surface. Date 3/15/81		
Rotary Air Driven Domestic Industrial Municipal	Artesian pressure lbs. per square inch. Date		
Rotary Mud	(12) WELL LOG: Diameter of well below casi		
(5) CASING INSTALLED: Steel 🛛 Plastic	Depth drilled 120 ft. Depth of completed well 120 ft.		
6	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.		
LINER INSTALLED:	MATERIAL F	From To SWL	
		0 4	
	sand & gravel (med)	5 7 7	
(6) PERFORATIONS: Perforated? ★Yes □ No		7 43 7	
Type of perforator used factory	CIAY DIOTH	43 51 7	
Size of perforations 1/8 in. by 3 in.		51 53 8	
240 perforations from 100 ft. to 120 ft.		53 84 8	
perforations from ft. to ft. to ft.	1	84 86 8	
perforations from ft. to ft.	clay (blue sandy)	86 104 8	
(7) SCREENS: Well screen installed? Yes XXNo	1 — • • • • • • • • • • • • • • • • • •	104 120 5	
Manufacturer's Name			
Type Model No		<u> </u>	
Diam. Slot Size Set from ft. to ft.			
Diam. Slot Size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? Yes X No If yes, by whom?	-		
field: gal/min. with ft. drawdown after hrs.			
·			
Air test gal/min. with drill stem at ft. hrs.			
Bailer test 22 gal./min. with 0 ft. drawdown after 2 hrs.			
rtesian flow g.p.m. emperature of water 73° Depth artesian flow encounteredft.	Work started 3/7/81 19 Completed	3/15/81 19	
	Work started 3/7/81 19 Completed Date well drilling machine moved off of well 3/17		
(9) CONSTRUCTION: Special standards: Yes □ No EX Well seal—Material used Cement grout			
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used		
Diameter of well bore to bottom of seal10in.	and information reported above are true to my best knowledge and belief.		
Diameter of well bore below seal	[Signed] (Drilling Machine Operator)	Date . 4/.10, 1981	
Number of sacks of cement used in well seal	Drilling Machine Operator's License No		
How was cement grout placed? from the bottom apwardly			
with presure grout pump & treime pipe.	Water Well Contractor's Certification:		
	This well was drilled under my jurisdiction and this report is true to		
Was pump installed? 20	the best of my knowledge and belief. Name Larry Root & Sons		
Was a drive shoe used? X Yes □ No Plugs Size: location ft.	(Person, firm or corporation) (Type or print)		
Did any strata contain unusable water? Yes Y No	Address ST RT 2-14692 Hwy 20 Burns, Oregon 97720		
Type of Water? depth of strata	[Signed] Surry To Root		
Method of sealing strata off	(Water Well Contractor)		
Was well gravel packed? ☐ Yes YNO Size of gravel:	Contractor's License No. 781Date . 4/10/81, 19		
CHAPPE PLACE I VIII			