

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED JUL 7 1964 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON (Please type or print)

Handwritten: Harn 321

State Well No. 23/30-354 State Permit No. G-4597

(1) OWNER:

Name Joe Monroe Address Butte Oregon, Hines

(2) LOCATION OF WELL:

County HARNEY Driller's well number SE 1/4 NE 1/4 Section 35 T. 23S R. 30E W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [checked] Deepening [ ] Reconditioning [ ] Abandon [ ] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [checked] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [checked] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 96' 9" ft. Gage 2.50 Threaded [ ] Welded [checked]

(7) PERFORATIONS:

Perforated? [ ] Yes [checked] No [ ] Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed [ ] Yes [checked] No [ ] Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled Clay Depth of seal 18 ft. Was a packer used? no Diameter of well bore to bottom of seal 9 in. Were any loose strata cemented off? [ ] Yes [checked] No Depth Was a drive shoe used? [checked] Yes [ ] No Was well gravel packed? [ ] Yes [checked] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [checked] Yes [ ] No Type of water? Sandy Depth of strata 8 to 10 ft Method of sealing strata off casing

(10) WATER LEVELS:

Static level 4 ft. below land surface Date May 13 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [checked] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 20 gal./min. with 0 ft. drawdown after 2 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [ ] Yes [checked] No

(12) WELL LOG:

Diameter of well below casing 6" Depth drilled 110 ft. Depth of completed well 110 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include soil brown, sandy clay brown, water bearing black sand fine, brown + blue clay, fine red + black sand, fine black sand, sinter black water bearing.

Work started Mar. 7 1964 Completed Mar. 14 1964 Date well drilling machine moved off of well MAR. 15 1964

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME EARL SKINNER (SKINNER & SONS) (Person, firm or corporation) (Type or print)

Address CRINE OREGON

Drilling Machine Operator's License No. 156

[Signed] Mrs. Forrest Skinner (Water Well Contractor)

Contractor's License No. 372 Date 6-10 1964