NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report			
are to be filed with the WATER WELL REPORT			
within 30 days from the date			
of well completion. WATER RESOURCES DEPT			
1) OWNER: (10) LOCATION OF WELL:			
ume C.O. & Mary Salsbery County HARNEY Driller's well number			
ddress Rt. L. Box 74	SE 1/4 SE 1/4 Section 1 T.23S. R. 31E. W.M.		
Burns, Oregon 97720	Bearing and distance from section or subdivision corner		
2) TYPE OF WORK (check):	480 A North \$ 135 West of the		
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐	SE corner of Sec 1		
f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.		
3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 22 ft.		
otary Driven Domestic Industrial Municipal	Static level 11 ft. below land surface. Date 9-6-79		
☐ Jetted ☐ Irrigation ☑ Test Well ☐ Other ☐			. م
	Artesian pressure lbs. per squar	e men. Date (9 <u>-6-7</u> 9
5) CASING INSTALLED: Threaded Welded			
12" Diam. from	Depth drilled 225 ft. Depth of completed well 216 ft.		
"Diam. from	Formation: Describe color, texture, grain size and structure of materials:		
Diam. from ft. to ft. Gage	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in		
6) PERFORATIONS: Perforated? X Yes	position of Static Water Level and indicate prin		
ype of perforator used Luvered	MATERIAL	From To	swL
size of perforations 3 in. by 1/8 in.	Top soil	0 4	
11.52 perforations from 8.0 ft. to 1.04 ft.	Clay	4 22	
23.04 perforations from 114 ft. to 162 ft.	Gravel	22 26	
11.52 perforations from 182 ft. to 206 ft.	Gray clay	26 37	
7) SCREENS: Well screen installed? Yes No	Sand & gravel	37 54	
Manufacturer's Name	Clay	54 76 76 85	
TypeModel No.	Medium_sand Clay	85 89	
Diam Slot size Set from ft. to ft.	Sand & gravel	89 100	
Diam Slot size Set from ft. to ft.	Tan clay	100 115	
8) WELL TESTS: Drawdown is amount water level is	Sand & gravel	115 117	
lowered below static level	Pumice	117 162	
a pump test made? Yes \(\text{No If yes, by whom?} \) \(\text{W.W.W.} \)	Clay stone	162 187	
deld: Joo gal./min. with offt. drawdown after hrs.	Soft Sandstone	187 205	
" " "	Claystone Green claystone	205 212	
" " "	Green Crays wine	1120 8127	· · · · · · · · · · · · · · · · · · ·
er test gal./min. with ft. drawdown after hrs.			
sian flow g.p.m.	=		
Temperature of water 60 Depth artesian flow encountered	Work started 9-4 19 79 Complete		19 79
9) CONSTRUCTION: SEP 11 1979	Date well drilling machine moved off of well	9-6	19 79
Vell seal-Material used cement grout	I—Material used <u>Cement grout</u> Drilling Machine Operator's Certification:		
Vell sealed from land surface to 18 WATER RESOURCES I			
Diameter of well bore to bottom of seal	best knowledge and belief.		
Diameter of well bore below seal	[Signed] - and Allebate 9-6 19 79		
mber of sacks of cement used in well seal 60 sacks (Orilling Machine Operator) Was cement grout placed gravity flow Drilling Machine Operator's License No. 103.5			
How was cement grout placed? gravity flow	Drining inclinic Operator's incluse two instances		
	Water Well Contractor's Certification:		
	This well was drilled under my jurisdiction and this report is		
Was a drive shoe used? ☐ Yes 🌠 No Plugs Size: location ft.	true to the best of my knowledge and belief.		
Did any strata contain unusable water? Yes No	Name Western Water Wells Inc. (Type or print)		
Type of water? depth of strata	Address P. O. Box 2940 Forns, Oregon		
nod of sealing strata off			
is well gravel packed? X Yes No Size of gravel: 3/8 [Signed] Water Well Contractor)			
Fravel placed from 18 ft. to 225 ft.	Contractor's License No	9-6	19.79
			•

Gravel placed from