

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED

AUG 10 1966

WATER WELL REPORT

Harney  
354

State Well No. 23/31-5

State Permit No.

STATE ENGINEER OF OREGON  
SALEM, OREGON  
(Please type or print)

(1) OWNER:

Name ERAN RAY  
Address BURNS OREGON

(2) LOCATION OF WELL:

County HARNEY Driller's well number  
1/4 SW 1/4 Section 5 T. 235 R. 31 E W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
10" Diam. from 103 ft. to 213 ft. Gage STD.  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
5/8 X 12" perforations from 101 ft. to 111 ft.  
1/4 X 10" perforations from 98 ft. to 108 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
In. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal \_\_\_\_\_  
Depth of seal \_\_\_\_\_ ft. Was a packer used? \_\_\_\_\_  
Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 18 ft. below land surface Date 6/30/66  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "  
Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 10"  
Depth drilled 213 ft. Depth of completed well 213 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SET 10" LINER FROM		
103 FT TO 213		
SET ON ROCK BOTTOM		
PUMPING CLEAR WATER		
VERY LITTLE SAND		
THIS WELL SHOULD BE		
DRILLED DEEPER TO		
OBTAIN MORE WATER		
PRESENT YIELD ABOUT		
450 G.P.M. AT 60 FT D.D.		

Work started 6/30/66 19 \_\_\_\_\_ Completed 7/13/66 19 \_\_\_\_\_  
Date well drilling machine moved off of well 11 11 19 \_\_\_\_\_

(13) PUMP:

Manufacturer's Name WESTERN  
Type: TURBIN H.P. ?

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Edgar L Koenevman  
(Person, firm or corporation) (Type or print)  
Address P.O. # 327 BURNS ORE  
Drilling Machine Operator's License No. 128  
[Signed] Edgar L Koenevman  
(Water Well Contractor)  
Contractor's License No. 323 Date June, 19 66