

File Original and
First Copy with the
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. _____

State Permit No. _____

(1) OWNER:
Name: RAYMOND VOEGTLY
Address: 2404 EGAN BURNS, OREGON

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? E.K.
Yield: 780 gal./min. with 6.3 ft. drawdown after 4 hrs
" 780 " " 6.1 " " 4 1/2 "

(2) LOCATION OF WELL:
County _____ Owner's number, if any _____
SE 1/4 SW 1/4 Section 34 T. 25 R. 30 E.W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well 16" inches
Depth drilled _____ ft. Depth of completed well 165 ft
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in item 11.

(4) PROPOSED USE (check): (5) TYPE OF WELL:
Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

MATERIAL	FROM	TO
SANDY SOIL	0	26
GREY SANDY CLAY	26	72
SANDY CINDERS	72	105
CINDERS	105	165

(6) CASING INSTALLED: Threaded Welded
16" Diam. from 0 ft. to 60 ft. Gage 25
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used _____
SIZE of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 20 ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 34 ft. below land surface Date _____
Artesian pressure _____ ft. per square inch Date _____
Log Accepted by: _____
[Signed] Raymond Voegtly Date 5-28 1962
(Owner)

Work started MAY 1 1962 Completed MAY 11 1962

(13) PUMP:
Manufacturer's Name _____
Type: TURBINE H.P. 50

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Edgar J. Moeneman
(City, firm, or corporation) (Type or print)
Address # Box 296 Burns, O.
Driller's well number _____
[Signed] Edgar J. Moeneman
(Well Driller)
License No. 323 Date May 24 1962

(USE ADDITIONAL SHEETS IF NECESSARY)

RECEIVED
JAN 13 2006
WATER RESOURCES DEPT
SALEM, OREGON