

**RECEIVED**

JAN 12 1950

**STATE ENGINEER  
SALEM, OREGON**

Application No. U \_\_\_\_\_  
Permit No. U \_\_\_\_\_  
Well No. \_\_\_\_\_

REPORT ON COMPLETION OF WELL

(Note: This report should be submitted to the State Engineer, Salem, Oregon, as soon as possible after the well is completed. If more than one well is covered by this permit, a separate report shall be filed for each)

Date of Report JAN 10., 1950

1. Location of well: \_\_\_\_\_ of Section 1 Twp. 23S Rge. 31E, W. M.
2. Name of nearest natural surface stream POISON CREEK
3. Distance from well to that stream: 3000 feet.
4. If the well is less than 1300 feet from a natural surface stream, give the difference in elevation between the ground surface at the well and the lowest point in stream channel: \_\_\_\_\_ feet.
5. Date of beginning drilling or digging ABOUT JULY 1, 1949
6. Date well was completed DEC. 1 1949

7. LOG OF MATERIALS ENCOUNTERED

Character of Material	Depth at which encountered	Thickness of stratum
TOP SOIL	At surface	ft.
TOP SOIL	15 ft.	ft.
SAND & GRAVEL	40 ft.	25 ft.
BLUE CLAY	63 ft.	23 ft.
BROWN SAND	73 ft.	10 ft.
SANDY WHITE CLAY	85 ft.	12 ft.
GRAVEL	88 ft.	3 ft.
SANDY WHITE CLAY	90 ft.	2 ft.
LOOSE SAND & SAND	120 ft.	30 ft.
Remarks: <u>SAND &amp; SAND ROCK</u>	<u>231</u>	<u>111 ft.</u>

WELL INFORMATION

8. Diameter of well 14" inches. Depth of well 231 feet.
9. Depth at which water was first encountered 17 feet.
10. Water level when completed: 8 feet below ground surface.
11. Additional information regarding well; such as soil conditions, quick sand, caves, obstructions, rock, etc.:

14" x 3/16 I.D. WELDED STEEL CASING TO 231 FT. 0 TO 62' PLAIN - 62' - 231' PERFORATED

WELL DRAWS DOWN TO 125' WITHIN 10 MINUTES AND COMES BACK TO WITHIN 5 TO 10' IN 3 MIN. AFTER PUMP IS SHUT DOWN.

July 5, 1949

Riley & Sewell  
Box 542  
Burns, Oregon

Gentlemen:

This acknowledges receipt of Form A, being notice of the beginning of construction under Permit No. **U-259** in the name of **Riley & Sewell.**

This report has been filed with other matter pertaining to the water right, and the permit is in good standing until October 1, 19 ~~50~~ when under its terms, construction should be completed.

Very truly yours,

*Chas. E. Stricklin*

CHAS. E. STRICKLIN  
State Engineer