

(1) OWNER: SALEM, OREGON
 Name T. J. Duhaime + Bessie Duhaime
 Address Burns Oregon

(2) LOCATION OF WELL:
 County Harney Owner's number, if any— FIVE
 R. F. D. or Street No. _____

Bearing and distance from section or subdivision corner
Well No. 530 set N. and 1050
ft. E. from SW. corner Sec. 22
1/4 of 23 S. Range 32 E. W. M.

(3) TYPE OF WORK (check):
 New well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
 Domestic Industrial Municipal
 Irrigation Test Well Other

(5) EQUIPMENT:
 Rotary
 Cable
 Dug Well

(6) CASING INSTALLED:
 Threaded Welded
 If gravel packed _____

| FROM | ft. to | Gage or Wall | Diameter of Bore | ft. | from ft. | to ft. |
|------|--------|---------------|------------------|------|----------|--------|
| 72 | 121 | 8" Diam. 3/8" | 8" | 3/8" | | |
| " | " | " | " | " | " | " |
| " | " | " | " | " | " | " |
| " | " | " | " | " | " | " |
| " | " | " | " | " | " | " |
| " | " | " | " | " | " | " |

 Type and size of shoe or well ring 8" ball
 Describe joint welded Size of gravel: _____

(7) PERFORATIONS:
 Type of perforator used cut by torch
 SIZE of perforations 6 in., length, by 1/4 in.

| FROM | ft. to | ft. | per foot | No. of rows |
|------|--------|-----------|----------|-------------|
| 50 | 65 | 8" casing | " | " |
| " | 65 | " | " | " |
| " | 120 | " | " | " |
| " | 150 | " | " | " |

 6" long vertical alternating rows screens
 SCREENS: approximately 1/4" mesh apart.
 Give Manufacturer's Name, Model No. and Size none.

(8) CONSTRUCTION:
 Was a surface sanitary seal provided? Yes No To what depth 30 ft.
 Were any strata sealed against pollution? Yes No
 If yes, note depth of strata _____
 FROM Ring was welded to casing to
prevent surface water from running
 METHOD OF SEALING into well

(9) WATER LEVELS:
 Depth at which water was first found 1.5 ft.
 Standing level before perforating Part in pipe before ft.
 Standing level after perforating part in well ft.

Log Accepted by:
 [Signed] T. J. Duhaime Dated Sept 5, 1955
Bessie Duhaime Owner

(10) WELL TESTS:
 Was a pump test made? Yes No If yes, by whom? Owner
 Yield: 600 gal./min. with 50 ft. draw down after 20 hrs.
 " " " " " " " "

Artesian flow g.p.m.
 Shut-in pressure lbs. per square inch.
 Baller test g.p.m. with ft. drawdown
 Temperature of water Was a chemical analysis made? Yes No
 Was electric log made of well? Yes No

(11) WELL LOG:
 Diameter of well, 8" x 6" inches.
 Total depth 250 ft. Depth of completed well 250 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| 1 ft. to | 16 ft. |
|----------|------------------------|
| 16" | 20" Brown quick sand |
| 20" | 40" " " " |
| 40" | 45" Blue shale |
| 45" | 65" " " " |
| 65" | 70" gravel |
| 70" | 75" Blue shale |
| 75" | 85" " " " |
| 85" | 90" sand-shale |
| 90" | 95" " " " |
| 95" | 100" " " " |
| 100" | 105" " " " |
| 105" | 110" Blue sand |
| 110" | 125" " " " |
| 125" | 130" Blue shale sticky |
| 130" | 135" sand and shale |
| 135" | 145" " " " |
| 145" | 150" Blue shale sticky |
| 150" | 160" " " " |
| 160" | 165" gravelly sand |
| 165" | 170" variegated shale |
| 170" | 180" " " " |
| 180" | 190" " " " |
| 190" | 200" " " " |
| 200" | 210" " " " |
| 210" | 220" sand and shale |
| 220" | 240" Black shale |
| 240" | 250" Blue shale |

Ground elevation at well site 41.40 feet above mean sea level.
 Work started Aug 25 1955 Completed Sept 5 1955

Well Driller's Statement:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 NAME PAUL G CHRISLEY
 (Person, firm, or corporation) (Typed or printed)
 Address BURNS OREGON
 Driller's well number _____
 [Signed] Paul G Chrisley
 (Well Driller)
 License No. NO Dated Sept 5, 1955