## STATE OF OREGON

## WATER WELL REPORT

(as required by ORS 537.765)

RECEIVED

NOV 2 1 1984

195/26E 29ac

PLEASE TYPE or PRINT IN WATER RESOURCES DEPT. (for official use only)

	SALEM. OREGON
(1) OWNER:	(10) LOCATION OF WELL by legal description:
Name U.S.D.A. Forest Service	County Harney SW 14 NE 14 of Section 29 of
Address P. O. Box 3623	Township 19S Range 26E WM
City Portland State Oregon	(Township is North or South) (Range is East or West)  Tax Lot Lot Block Subdivision
(2) TYPE OF WORK (check):	MAILING ADDRESS OF WELL (or nearest address)
New Well \( \) Deepening \( \Boxed{\omega} \) Reconditioning \( \Boxed{\omega} \) Abandon \( \Boxed{\omega} \)	Delintment Lake Campground #2
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL of COMPLETED WELL:
Rotary Air 😡 Driven 🗆 Domestic 😡 Industrial 🗆 Municipal 🗆	Depth at which water was first found 82 ft.
Rotary Mud Dug Irrigation Withdrawal Reinjection	Static level 32 ft. below land surface. Date 10-11-84
Other:  Other:  Grounding Test	Artesian pressure lbs. per square inch. Date
Doled I Notation I will be a second in the s	(12) WELL LOG: Diameter of well below casing
'5) CASING INSTALLED: Steel Threaded Welded Head	Depth drilled 1U4 ft. Depth of completed well 1U4 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness
8	and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal
ft. to ft. Gauge	water-bearing strata.
LINER INSTALLED: Steel XI Plastic Threaded Welded XI	MATERIAL From To SWL
6	Overburden 0 4
	Soft grey lava rock 4 26 32
(6) PERFORATIONS: Perforated?	Brown coarse sandstone 26 82
27	Broken black & brown rock WB 82 104 -
perforations from	
perforations from the comment of the	
(7) SCREENS: Well screen installed? ☐ Yes ☒ No Manufacturer's Name	
Manufacturer's Name	
Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	
Drawdown is amount water level is lowered	
DOLON SWEET TO THE	
Was a pump test made?    Yes    No If yes, by whom?	
d: gal./min. with ft. drawdown after hrs.	
gal./min. with drill stem at ft. hrs.	
Air test gal./min. with drill stem at ft. nrs.  Bailer test 12 gal./min. with 4 ft. drawdown after 1 hrs.	
Artesian flow g.p.m.	
perature of water Depth artesian flow encountered ft.	10-10-84
CONSTRUCTION: Special standards: Yes \( \subseteq \) No \( \subseteq \)	Date work started HI-9-84 completed 10-11-84
Well seal—Material usedCement	Date well drilling machine moved off of well 10-11- 184
Well sealed from land surface to $\frac{-18}{100}$ ft.	(unbonded) Water Well Constructor Certification (if applicable):
Diameter of well bore to bottom of seal12 in.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal8 in.	
Amount of sealing material	[Signed] Date /// Date // Dat
How was cement grout placed? DIESSUIE GROUTED	(bonded) Water Well Constructor Certification:  Bond 2206234
	(number) (Surety Company Name)
Was pump installed? Yes hand pump Depth 60 ft.	On behalf of Crawford Well Drilling, Inc.  (type or print name of Water Well Constructor)
Was a drive shoe used?    Yes    No Plugs Size: location ft.	•
Did any strata contain unusable water?	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:
Type of Water? depth of strata	
Method of sealing strata off	(Signed)
Was well gravel packed?	(Dated) 11-16-84
Graver praced from 1t. to 1t.	l