NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 23/32-32
State Permit No.

(1) OWNER:
Name T.J. DUHAIME
Address BURNS OREGON

(2) LOCATION OF WELL:
County HARNEY Driller's well number 17
NE ¼ ¼ Section 32 T. 23S R. 32E W.M.
Bearing and distance from section or subdivision corner
300' WEST 50' SOUTH OF THE NORTH EAST CORNER OF SEC 32

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒
12" Diam. from 0 ft. to 224 ft. Gage 1/4"
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No
Type of perforator used TORCH CUT
Size of perforations 3/16 in. by 4 in.
1300 perforations from 90 ft. to 210 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal 24'-30"X3/8" Conductor
Depth of seal ft. Was a packer used? No Casing
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/4 Minus
Gravel placed from 0 ft. to 224 ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 30 ft. below land surface Date JUNE 30-63
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? McGUIRE
Yield: 1000 gal./min. with 100 ft. drawdown after 10 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing
Depth drilled 224 ft. Depth of completed well 224 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
TOP SOIL	0	8
SAND FINE	8	22
CLAY BLUE	22	60
GRAVEL MED	60	62
CLAY BLUE	62	96
GRAVEL MED	96	98
CLAY BLUE	98	200
GRAVEL MED	200	210
CLAY BLUE	210	224

A 30"X 3/8" X 24' CONDUCTOR CASING WAS INSTALLED TO SEAL OF TOP WATER CONDUCTOR CASING WAS INSTALLED IN 30" HOLE AND STOPPED IN CLAY SEALED WITH PUDDLED BENTONITE

Work started 6-19 1963 Completed 6-28 1963
Date well drilling machine moved off of well 6-29 1963

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME McGUIRE DRILLING Co
(Person, firm or corporation) (Type or print)
Address Box 909 BURNS ORE
Drilling Machine Operator's License No. 81
[Signed] J. L. McGuire
(Water Well Contractor)
Contractor's License No. 383 Date 7-2, 1963

(USE ADDITIONAL SHEETS IF NECESSARY)