NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

# WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED NOV 3 1972 STATE ENGINEER SALEM, OREGON

State Well No. 23S/32½E-13 6a
State Permit No. G-5951

6&8 HARN

## (1) OWNER:
Name Oscar Indrebo
Address 9925 W 20 Apt. #11 Lakewood, Colo.

## (2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

## (3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

## (4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

## (5) CASING INSTALLED:
Threaded ☐ Welded ☒
12 " Diam. from 0 ft. to 40 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

## PERFORATIONS:
Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

## (7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

## (8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? driller
Yield: 1467 gal./min. with 22 ft. drawdown after 12 hrs.
" " "
" " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

## (9) CONSTRUCTION:
Well seal—Material used bentonite
Well sealed from land surface to 18' ft.
Diameter of well bore to bottom of seal 15 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 12 sacks
Brand name of bentonite Shamrock
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

## (10) LOCATION OF WELL:
County Harney Driller's well number
NE¼ NW¼ Section 13 T. 23 R. 32½ E W.M.
Bearing and distance from section or subdivision corner
668' W of center section line
668' N of center section line

## (11) WATER LEVEL: Completed well.
Depth at which water was first found 228 ft.
Static level 9'11" ft. below land surface. Date 9-9-72
Artesian pressure lbs. per square inch. Date

## (12) WELL LOG:
Diameter of well below casing 12"
Depth drilled 239 ft. Depth of completed well 239 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

| MATERIAL | From | To | SWL |
|---|---|---|---|
| black clay | 0 | 105 | |
| brown clay w/a little gravel & small rocks | 105 | 130 | |
| hard brown clay | 130 | 165 | |
| grey sandstone | 165 | 185 | |
| blue clay | 185 | 228 | |
| harder blue clay w/ water | 228 | 231 | 9'11" |
| grey rock | 231 | 232 | |
| hard blue clay | 232 | 237 | |
| black rock | 237 | 238 | |
| blue clay | 238 | 239 | |

Work started 8-29 19 72 Completed 9-8 19 72
Date well drilling machine moved off of well 9-10 1972

**Drilling Machine Operator's Certification:**
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Forrest Skinner (Drilling Machine Operator) Date 10-1, 1972
Drilling Machine Operator's License No. 10

**Water Well Contractor's Certification:**
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Skinner & Sons (Person, firm or corporation) (Type or print)
Address Crane, Oregon 97732
[Signed] Catherine Skinner (Water Well Contractor)
Contractor's License No. 372 Date 10-1-, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119