

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

STATE ENGINEER
SALEM OREGON

State Well No.

State Permit No.

23/33-31

6-8173

(1) OWNER:

Name James Campbell

Address West Bennett & Hilltop
Hines, Oregon

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒
12" Diam. from 0 ft. to 220 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

2415-68

Static level 10 ft. below land surface Date 10-23-68*

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? driller

Flow: 150 gal./min. with 55 ft. drawdown after 5 min.

" " " "

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used puddled clay

Depth of seal 18 ft.

Diameter of well bore to bottom of seal 15 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☒ Yes ☐ No

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Harney

Driller's well number

1/4 N.E. 1/4 Section 31 T.23S R.33E W.M.

Bearing and distance from section or subdivision corner

Center of NE 1/4 Sec. 31

(12) WELL LOG:

Diameter of well below casing 12"

Depth drilled 500 ft. Depth of completed well 500 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change
in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Sandy topsoil--brown	0	8	
clay brown	8	12	
sandy clay w/water	12	15	10
blue sandy clay w/water	15	175	"
blue clay	175	185	
blue sandy clay w/water	185	221	10
blue clay, small gravel & water	221	310	10
blue clay	310	500	
Insufficient water. Well capped by installing welded-on cap and abandoned till later date.			

Work started 10-23 1967 Completed 2-15 1968

Date well drilling machine moved off of well 3-1-68 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Frank Skinner Date Mar-9, 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 276

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Skinner & Sons
(Person, firm or corporation) (Type or print)

Address Crane, Oregon

[Signed] Catherine Skinner
(Water Well Contractor)

Contractor's License No. 372 Date 3-20, 1968